

Violation_Table

<u>Address</u>	<u>Violation Date</u>	<u>Violation</u>	<u>Description of Violation</u>
2922 Valley	6-26-1987	E	storm (window) broken
2924 Valley	6-26-1987	I	furnace room- support gas piping
2926 Valley	7-13-1987	I	debris/unsanitary
2922 Valley	6-22-1987	I	bedroom carpet- secure down
2926 Valley	10-22-1979	E	roof leaks
2926 Valley	10-22-1979	I	lavatory not bolted to the floor/ water leaks
2926 Valley	10-22-1979	E	no porch light
2926 Valley	10-22-1979	E	No front steps
2926 Valley	10-22-1979	I	infestation (vermin)
3006 Valley	11-18-2003	I	poor water heater/ refrigerator
3006 Valley	11-18-2003	I	hot switches
3006 Valley	11-18-2003	I	sparking outlets
3006 Valley	11-18-2003	I	mold in bedroom closet/cracked ceiling
3006 Valley	11-18-2003	I	cloudy water
3006 Valley	6-25-1998	I	old electrical-fire hazard
3006 Valley	6-22-98	E	chipped paint
3006 Valley	4-1-88	E	secure weatherhead to house
3006 Valley	4-1-88	I	oversized electric panel
3006 Valley	4-1-88	I	cracked window-living room
3006 Valley	4-1-88	I	insificient oulets-living room
3000 Valley	8-8-2001	E	chimney needs repair
3000 Valley	8-8-2001	E	chipped paint
3000 Valley	1-5-1997	E	trash/junk in yard
3000 Valley	7-31-1996	E	chipped paint
208-218 Union	2-23-2006	E	chipped paint
210 Union	2-23-2006	I	no base for lavatory
214 Union	2-23-2006	I	broken railing- top of stairs
210 Union	2-23-2006	I	smoke detectors- need hardwire
212 Union	2-23-2006	I	floor tile
210 Union	3-24-2006	I	smoke detectors- need hardwire
214 Union	3-24-2006	I	bathroom floor needs repair
214 Union	3-24-2006	I	fill breakers- electric
216 Union	3-24-2006	E	windows/screens need work
218 Union	3-24-2006	I	entry/weather tight-need work
208-218 Union	3-15-2003	E	chipped paint
208 Union	3-29-2001	E	abandoned vehicle
2008-218 Union	3-13-2000	E	shingles need repair
210 Union	3-13-2000	E	storms/screens need repair
212 Union	3-13-2000	I	Blow down leg
212 Union	3-13-2000	I	Funace to code
214 Union	3-13-2000	I	repair shower/faucet/paint
214 Union	3-13-2000	I	plug unused gas line
214 Union	3-13-2000	I	service panel- need cover
216 Union	3-13-2000	I	cluttered/dirty
216 Union	3-13-2000	I	need screens
216 Union	3-13-2000	I	hole in wall
216 Union	3-13-2000	I	gas/electric lines to code
216 Union	3-13-2000	I	outlet secure- utility room
218 Union	3-13-2000	I	water heater- replace
218 Union	3-13-2000	I	water heater- leak in pipe

Violation_Table

218 Union	3-13-2000	I	shower walls- repair
216 Union	3-13-2000	I	ceiling in kitchen- repair/paint
208-218 Union	2-23-2000	E	chipped paint
208 Union	12-18-1996	E	junk
208 Union	12-18-1996	I	furnace- repair
208 Union	12-18-1996	I	clutter/dirty
208 Union	12-18-1996	I	bedroom door
210 Union	12-18-1996	I	weather stripping- kitchen/living room
210 Union	12-18-1996	I	closet doors-repair
208-218 Union	6-4-1991	E	chipped paint
212 Union	6-4-1991	I	electrical box- cover
210 Union	6-4-1991	I	electrical box- cover
210 Union	6-4-1991	I	pressure relief valve (connection)-check
210 Union	6-4-1991	I	cracked windows
208 Union	6-4-1991	I	kitchen floor- replace
208 Union	6-4-1991	I	gas shut off valve
218 Union	6-4-1991	I	cracked windows
218 Union	6-4-1991	I	outlet covers- replace
218 Union	6-4-1991	I	screen- furnace room
216 Union	6-4-1991	I	blow down leg
214 Union	6-4-1991	E	leaky roof
214 Union	6-4-1991	I	screen
212 Union	10-23-1990	I	electrical box- cover
212 Union	10-23-1990	E	storm door- replace
212 Union	10-23-1990	I	carpet- tack down
214 Union	6-22-1987	I	loose floor board
218 Union	6-22-1987	E	junk in yard
218 Union	7-22-1987	I	debris/unsanitary
210 Union	7-13-1987	I	debris/unsanitary
2914 Valley	7-20-2005	E	outside light- to code
2914 Valley	7-10-2005	E	chipped paint
2914 Valley	8-26-2002	E	grass violation
2914 Valley	7-17-2000	I	screens- repair
2914 Valley	7-17-2000	I	dryer gas line- capped
2914 Valley	7-17-2000	I	screens- repair/replace
2914 Valley	7-17-2000	E	chipped paint
2914 Valley	8-22-1995	E	debris/unsanitary
2910 Valley	11-26-2003	I	smoke detectors- secure
2910 Valley	11-26-2003	I	outlets wont trip
2910 Valley	11-12-2003	E	chipped paint
2910 Valley	8-26-2002	E	grass- needs mowed
2910 Valley	11-17-1998	E	direct water from foundation
2910 Valley	11-17-1998	I	gas line- change / shut off valve
2910 Valley	11-11-1998	E	chipped paint
2910 Valley	11-24-1993	E	chipped paint
2910 Valley	11-24-1993	I	GFCI- replace
2910 Valley	11-24-1993	I	mold
2910 Valley	11-24-1993	I	windows- broken
2910 Valley	1-19-1989	E	needs renovation
2910 Valley	1-9-1989	E	yard light- repair
2910 Valley	1-9-1989	I	kitchen/ hallway floor- replace

Violation_Table

2910 Valley	1-9-1989	I	inadequate outlets
2910 Valley	1-9-1989	E	storm doors- repair
2910 Valley	1-9-1989	I	electric- inadequate
209-219 Union	1-4-2006	E	chipped paint
209-219 Union	1-25-2006	I	broken glass
209-219 Union	1-25-2006	I	outlets- secure
213 Union	1-25-2006	E	screens
215 Union	1-25-2006	E	screens
217 Union	1-25-2006	E	screens
209 Union	1-25-2006	I	hardwire
215 Union	1-25-2006	I	hardwire
215 Union	1-25-2006	E	storm door closure
217 Union	1-25-2006	E	storm door closure
215 Union	3-24-2003	I	door closure
217 Union	3-24-2003	I	furnace room- connect outlet
209 Union	10-20-2000	I	bathroom ceiling- repair
211 Union	10-20-2000	I	vent dryer out
211 Union	10-20-2000	I	screens
211 Union	10-20-2000	I	closet doors- repair
213 Union	10-20-2000	I	gas line- cap
213 Union	10-20-2000	E	weather stripping
213 Union	10-20-2000	I	base boards- missing
215 Union	10-20-2000	I	faucet leak
215 Union	10-20-2000	I	outlets- secure
217 Union	10-20-2000	I	window- repair
209-219 Union	10-17-2000	E	chipped paint
217 Union	1-30-1997	E	storm window
217 Union	1-30-1997	E	screens- repair
217 Union	1-30-1997	I	cover outlet
215 Union	1-30-1997	E	weather strip
215 Union	1-30-1997	I	ceiling- clean/paint
215 Union	1-30-1997	I	window locks
213 Union	1-30-1997	E	weather strip
213 Union	1-30-1997	I	dirty
211 Union	1-30-1997	E	weather strip
211 Union	1-30-1997	I	blow down leg
209 Union	1-30-1997	I	kitchen floor- repair/replace
209 Union	1-30-1997	I	smoke detectors- attach
209-219 Union	1-5-1997	E	chipped paint
209 Union	1-16-1994	I	dirty
211 Union	1-16-1994	I	ceiling- secure
213 Union	1-16-1994	I	electrical fire
209-219 Union	1-13-1994	E	chipped paint
209-219 Union	6-4-1991	E	chipped paint
209 Union	6-4-1991	I	bathroom floor- replace
209 Union	6-4-1991	I	tub wall- repair/replace
211 Union	6-4-1991	I	replace cracked glass
211 Union	6-4-1991	I	mold
211 Union	6-4-1991	I	closet track- repair/replace
211 Union	6-4-1991	I	switch covers- secure
219 Union	6-4-1991	I	faucet leak

Violation_Table

219 Union	6-4-1991	I	main breaker out
219 Union	6-4-1991	I	cracked glass
219 Union	6-4-1991	E	window screen
215 Union	6-4-1991	I	cover electric panel
215 Union	6-4-1991	E	sorm windo- repair
215 Union	6-4-1991	I	closet door- repair
217 Union	6-4-1991	I	cover electric panel
217 Union	6-4-1991	I	leaky faucet
219 Union	12-22-1987	E	no handrail
209 Union	12-2-1987	E	handrail
209 Union	10-8-1986	I	tub ledge- seal
211 Union	10-8-1986	I	water heater vent- secure
211 Union	10-8-1986	I	install trim board- stairs
213 Union	10-8-1986	I	water heater control valve
213 Union	10-8-1986	I	install trim board- stairs
215 Union	10-8-1986	I	light fixture- secure
215 Union	10-8-1986	I	closet door- repair
215 Union	10-8-1986	I	install trim board- stairs
215 Union	10-8-1986	I	burnt receptacle
217 Union	10-8-1986	I	water heater vent- secure
217 Union	10-8-1986	I	ducts- seal
219 Union	10-8-1986	E	porch roof- paint/repair
219 Union	10-8-1986	I	base molding- install
209-219 Union	3-14-1986	I	bare wires/electrical not to code
227 Union	4-14-2005	I	ceiling light- short
227 Union	4-14-2005	I	storm window/screens- repair
227 Union	4-14-2005	I	fire extinguisher- mount
227 Union	4-14-2005	I	tub drain- repair
227 Union	4-14-2005	E	storm door- repair
227 Union	4-14-2005	I	cabinets- repair
223-229 Union	3-2-2004	E	trash in yard
223 Union	3-2-2004	I	plug lavatory
223 Union	3-2-2004	E	storm window/screens
223 Union	3-2-2004	I	fire extinguisher- charge
225 Union	3-2-2004	I	outlets wont trip
225 Union	3-2-2004	I	screens/storm window
225 Union	3-2-2004	I	loose carpet- stairs
225 Union	3-2-2004	I	smoke detectors/hardwire- stairs
225 Union	3-2-2004	E	weather tight- repair
225 Union	3-2-2004	I	broken windows
225 Union	3-2-2004	I	kitchen walls- repair
225 Union	3-2-2004	I	door locks- repair
225 Union	3-2-2004	I	kitchen outlets- repair
225 Union	3-2-2004	I	infestation (vermin)
225 Union	3-2-2004	I	sink- leaks
225 Union	3-2-2004	I	fire extinguisher
227 Union	3-2-2004	I	broken windows
227 Union	3-2-2004	I	switch covers
227 Union	3-2-2004	I	smoke detectors
227 Union	3-2-2004	I	outlets wont trip
223 Union	6-19-2001	E	trash/debris/trees

Violation_Table

229 Union	6-21-2001	E	grass/weeds
223-229 Union	4-10-2001	E	front porch roofs- replace
223 Union	4-10-2001	E	screens-repair/need
223 Union	4-10-2001	I	window stops- repair/replace
225 Union	4-10-2001	I	GFCI
225 Union	4-10-2001	E	window screens
225 Union	4-10-2001	I	outlet/switches covers
225 Union	4-10-2001	I	broken windows
225 Union	4-10-2001	I	sink- hooked up
225 Union	4-10-2001	I	stove- secure outlet
227 Union	4-10-2001	I	lockset- repair
227 Union	4-10-2001	I	broken windows
227 Union	4-10-2001	I	carpet- repair/replace
227 Union	4-10-2001	I	storms/screens- replace
227 Union	4-10-2001	E	storm door closure
227 Union	4-10-2001	I	outlets- replace
227 Union	4-10-2001	I	gas line- cap
229 Union	4-10-2001	E	window screen- replace
229 Union	4-10-2001	I	ceiling/walls- clean/paint
229 Union	4-10-2001	I	smoke detectors- repair/replace
229 Union	4-10-2001	E	storm door/closure- repair
229 Union	4-10-2001	I	kitchen floor- repair/replace
229 Union	4-10-2001	I	dirty/cluttered
223-229 Union	4-10-2001	E	chipped paint
225 Union	12-30-1998	I	infestation (vermin)
225 Union	12-30-1998	I	kitchen sink- repair
225 Union	12-30-1998	I	uneven floor- living room
223-229 Union	2-21-1998	E	chipped paint
223-229 Union	7-7-200	E	misc. junk
227 Union	4-15-1998	E	demo. material/junk
223 Union	2-27-1995	I	too cluttered to inspect
223 Union	4-20-1992	I	unkept floor covering
223 Union	4-20-1992	I	kitchen- grease film
223 Union	4-20-1992	I	cardboard boxes
223 Union	4-20-1992	I	fixtures unsanitary
223 Union	4-20-1992	I	infestation (vermin)
223 Union	4-20-1992	I	garbage
223 Union	4-20-1992	I	fire hazards
229 Union	2-4-1992	I	outlets
223 Union	2-7-1992	I	hole in ceiling
223 Union	2-7-1992	I	bedrooms too crowded
223 Union	2-7-1992	I	kitchen floor- repair
225 Union	2-7-1992	I	tub- seal
227 Union	2-7-1992	I	stairs carpet- remove
223-229 Union	1-7-1991	E	chipped paint
229 Union	1-7-1991	I	outlets
227 Union	1-7-1991	I	smoke alarm
227 Union	11-14-1989	I	lights- secure
223 Union	11-14-1989	I	no GFCI
229 Union	11-14-1989	I	broken window
229 Union	11-14-1989	I	cracked storm

Violation_Table

229 Union	11-14-1989	I	door jams- repair
229 Union	11-14-1989	I	outlets- inoperable
229 Union	11-14-1989	E	weather proofing
225 Union	3-17-1989	I	over occupancy
223 Union	1-23-1989	I	romex- remove
223 Union	1-23-1989	I	electrical- not up to date
223 Union	1-23-1989	I	bedroom- no access to windows
225 Union	1-23-1989	I	bathroom- remove carpet
223-225 Union	1-23-1989	I	smoke alarms- repair
223-225 Union	1-23-1989	I	peeling paint
223-225 Union	1-23-1989	E	peeling paint
223-225 Union	1-23-1989	I	cracked windows
223-225 Union	1-23-1989	I	electric- not up to date
227 Union	1-22-1989	I	entry door- replace lock
227 Union	1-22-1989	I	change pressure relief
227 Union	1-22-1989	I	blow down leg
227 Union	1-22-1989	I	romex- remove
227 Union	1-22-1989	I	shut off valve
227 Union	1-22-1989	I	outlets
227 Union	1-22-1989	I	lead paint
229 Union	1-22-1989	I	electric- overloaded
229 Union	1-22-1989	I	gas shut off valve
229 Union	1-22-1989	I	outlet covered
229 Union	1-22-1989	I	fire extinguisher- recharge
229 Union	1-22-1989	I	entry door- repair
235-241 Union	6-29-1982	I	gas valves
235-241 Union	6-29-1982	I	smoke detector
235-241 Union	6-29-1982	I	fire extinguisher
301-307 Union	7-9-2003	E	chipped paint
301 Union	8-28-2003	I	tub surround- repair
301 Union	8-28-2003	I	walls need worked on
301 Union	8-28-2003	I	carpet- worn out
301 Union	8-28-2003	I	carpet- trip hazard on stairs
301 Union	8-28-2003	E	weather stripping
303 Union	8-28-2003	I	cracked windows
303 Union	8-28-2003	I	smoke detectors- repair
303 Union	8-28-2003	I	fire extinguisher
305 Union	8-28-2003	I	plumbing- leak
307 Union	8-28-2003	I	bathroom floor- repair
307 Union	8-28-2003	I	broken windows
307 Union	8-28-2003	I	weather stripping
307 Union	8-28-2003	I	plumbing- leak
307 Union	8-28-2003	I	fire extinguisher
301-307 Union	6-27-2001	E	chipped paint
301-307 Union	6-26-2001	E	steps- repair
307 Union	6-26-2001	E	storm/screens
307 Union	6-26-2001	I	outlet- repair/replace
307 Union	6-26-2001	I	smoke detector- repair
307 Union	6-26-2001	E	furniture on porch
307 Union	6-26-2001	I	screens
307 Union	6-26-2001	E	storm door- replace/repair

Violation_Table

305 Union	6-26-2001	I	screen
305 Union	6-26-2001	E	weather stripping- secure
305 Union	6-26-2001	I	kitchen- paint
305 Union	6-26-2001	I	ceiling- repair (leak)
303 Union	6-26-2001	I	water pressure
303 Union	6-26-2001	E	screens- need/repair
303 Union	6-26-2001	I	outlets- repair
303 Union	6-26-2001	I	tile- repair
303 Union	6-26-2001	I	fire extinguisher
301 Union	6-26-2001	I	screens
301 Union	6-26-2001	I	weather stripping- secure
301-307 Union	3-22-1989	I	panels- label
303 Union	3-22-1989	I	combustion- furnace room
301-307 Union	9-20-0988	I	water lines- replace
301-307 Union	9-20-1988	I	romex
301-307 Union	9-20-1988	I	breaker box- additional
301-307 Union	9-16-1988	I	blow down leg
305 Union	9-16-1988	I	breaker box- replace/ extend
300-306 Ordinance	9-12-1989	E	chipped paint
300-306 Ordinance	3-16-1989	E	chipped paint- windows
300-306 Ordinance	3-16-1989	I	varnish- floors
300-306 Ordinance	3-16-1989	I	closets- paint
302 Ordinance	3-16-1989	I	kerosene- used for heat
302 Ordinance	3-16-1989	I	loose tile
306 Ordinance	3-16-1989	I	housing code- bare minimum
300 Ordinance	4-12-1989	I	windows- chipped paint
307 Ordinance	2-15-1989	I	water pressure- in adequate
307 Ordinance	2-15-1989	I	threshold- repair/ replace
307 Ordinance	2-15-1989	I	infestation- pests
307 Ordinance	2-15-1989	I	paint
302 Ordinance	2-15-1989	I	shower- illegal
302 Ordinance	2-15-1989	I	tub walls- impervious
302 Ordinance	2-15-1989	I	water leak
302 Ordinance	2-15-1989	I	paint splatters
302 Ordinance	2-15-1989	I	illegal ceiling fans
300 Ordinance	1-16-1989	I	floors/doors/fixtures- unsafe
304 Ordinance	1-16-1989	I	
300 Ordinance	1-16-1989	I	water heater- unsafe
300 Ordinance	1-16-1989	I	doors/windows- locks
304 Ordinance	1-16-1989	I	
300 Ordinance	1-16-1989	I	outlets
304 Ordinance	1-16-1989	I	outlets
300-304 Ordinance	1-16-1989	I	smoke detectors
300-304 Ordinance	1-16-1989	I	fire extinguisher
300-304 Ordinance	1-16-1989	E	chipped paint
300-304 Ordinance	1-16-1989	I	chipped paint
300-306 Ordinance	1-16-1989	E	porches- paint
300-306 Ordinance	1-16-1989	I	ceilings leak
300 Ordinance	1-16-1989	I	screens/weather-proofing
304 Ordinance	1-16-1989	I	screens/ weather-proofing
300 Ordinance	1-16-1989	I	doors- repair

Violation_Table

304 Ordinance	1-16-1989	I	doors- repair
306 Ordinance	1-16-1989	I	windows- repair
300 Ordinance	1-16-1989	I	screens- repair
304 Ordinance	1-16-1989	I	screens- repair
300 Ordinance	1-16-1989	I	gas connections- unsafe
304 Ordinance	1-16-1989	I	gas connections- unsafe
304 Ordinance	1-16-1989	I	flooring- unsafe
304 Ordinance	1-16-1989	I	electric/gas lines- unsafe
300 Ordinance	1-16-1989	I	infestation- pests
304 Ordinance	1-16-1989	I	infestation- pests
302 Ordinance	1-16-1989	I	tub walls- impervious
302 Ordinance	1-16-1989	I	ceiling fans- improper wiring
300 Ordinance	1-16-1989		dirty/cluttered
304 Ordinance	1-16-1989	I	dirty/cluttered
300-306 Ordinance	10-4-1989	I	facilities- unsafe
300 Ordinance	10-4-1989	I	water heaters- unsafe
306 Ordinance	10-4-1989	I	water heaters- unsafe
302 Ordinance	10-4-1989	I	handrails
300-306 Ordinance	10-4-1989	I	windows/doors- no locks
300-306 Ordinance	10-4-1989	I	outlets
300 Ordinance	10-4-1989	I	fire extinguisher
304 Ordinance	10-4-1989	I	fire extinguisher
306 Ordinance	10-4-1989	I	fire extinguisher
300 Ordinance	10-4-1989	I	smoke detectors
302 Ordinance	10-4-1989	I	smoke detectors
300-306 Ordinance	10-4-1989	I	peeling paint
300-306 Ordinance	10-4-1989	E	peeling paint
300-306 Ordinance	10-4-1989	I	ceiling leaks
300-306 Ordinance	10-4-1989	I	screens- replace/repair
300-304 Ordinance	10-4-1989	I	doors- repair/replace
306 Ordinance	10-4-1989	I	broken windows
300-306 Ordinance	10-4-1989	I	ceilings- unsound
300-306 Ordinance	10-4-1989	E	wood surfaces- unfinished
300-306 Ordinance	10-4-1989	I	electrical- inadequate
300-306 Ordinance	10-4-1989	I	outlet covers- repair/replace
300-304 Ordinance	10-4-1989	I	gas connections- improper
302-306 Ordinance	10-4-1989	I	flooring- unsafe
302-306 Ordinance	10-4-1989	I	gas/electric- unsafe
302-306 Ordinance	10-4-1989	I	fire protection
302-306 Ordinance	10-4-1989	I	infestation- pest
302-306 Ordinance	10-4-1989	I	dirty/cluttered
300 Ordinance	5-20-1988	I	blow down leg
300 Ordinance	5-20-1988	I	gas line- replace
300 Ordinance	5-20-1988	I	outlet covers
300 Ordinance	5-20-1988	I	storm door
300 Ordinance	5-20-1988	I	weathertight
300 Ordinance	5-20-1988	I	walls- holes
300 Ordinance	5-20-1988	I	ceiling- repair
300 Ordinance	5-20-1988	I	smoke detector
300 Ordinance	5-20-1988	I	peeling paint
300 Ordinance	5-20-1988	E	peeling paint

Violation_Table

300 Ordinance	5-20-1988	I	locks- replace
300 Ordinance	5-20-1988	I	outlets- replace
300 Ordinance	5-20-1988	I	infestation- vermin
302 Ordinance	5-20-1988	I	outlets- replace
302 Ordinance	5-20-1988	I	switch covers- replace
302 Ordinance	5-20-1988	I	shower walls- replace
302 Ordinance	5-20-1988	I	ceiling- repair
302 Ordinance	5-20-1988	I	fixtures- improper wiring
302 Ordinance	5-20-1988	I	weathertight
302 Ordinance	5-20-1988	I	infestation- vermin
302 Ordinance	5-20-1988	I	peeling paint
302 Ordinance	5-20-1988	E	peeling paint
302 Ordinance	5-20-1988	I	smoke detector
302 Ordinance	5-20-1988	I	handrail
302 Ordinance	5-20-1988	I	screens
304 Ordinance	5-20-1988	I	water heater- shut off valve
304 Ordinance	5-20-1988	I	romex- unprotected
304 Ordinance	5-20-1988	I	ceiling- repair
304 Ordinance	5-20-1988	I	screens- repair/replace
304 Ordinance	5-20-1988	I	weathertight
304 Ordinance	5-20-1988	I	windows- repair/replace (cracked)
304 Ordinance	5-20-1988	I	peeling paint
304 Ordinance	5-20-1988	E	peeling paint
304 Ordinance	5-20-1988	I	bath floor- repair
304 Ordinance	5-20-1988	I	outlets- replace
304 Ordinance	5-20-1988	I	infestation- vermin
304 Ordinance	5-20-1988	I	dirty/cluttered
304 Ordinance	5-20-1988	I	fixtures- repair/replace
306 Ordinance	5-20-1988	I	blow down leg
306 Ordinance	5-20-1988	I	gas shut off valve
306 Ordinance	5-20-1988	I	furnace- unproper wiring
306 Ordinance	5-20-1988	I	quarterround- secure
306 Ordinance	5-20-1988	I	outlets
306 Ordinance	5-20-1988	I	windows- repair/replace (cracked)
306 Ordinance	5-20-1988	I	roof leaks
306 Ordinance	5-20-1988	I	ceiling leaks
306 Ordinance	5-20-1988	I	floors- replace/repair
306 Ordinance	5-20-1988	I	infestation- vermin
306 Ordinance	5-20-1988	I	infestation- pests
306 Ordinance	5-20-1988	E	brick- repair
300 Ordinance	5-10-1988	I	blow down leg- replace
306 Ordinance	5-20-1988	I	gas line- replace
306 Ordinance	5-20-1988	I	outlet covers
306 Ordinance	5-20-1988	E	storm door
306 Ordinance	5-20-1988	I	ceiling- repair (holes)
306 Ordinance	5-20-1988	I	door locks- replace
306 Ordinance	5-20-1988	I	infestation- vermin
306 Ordinance	5-20-1988	I	electrical- inadequate
302 Ordinance	5-20-1988	I	outlets- missing/broken
302 Ordinance	5-20-1988	I	shower walls- repair
302 Ordinance	5-20-1988	I	lights- rewire

Violation_Table

302 Ordinance	5-20-1988	I	weathertight
302 Ordinance	5-20-1988	I	ceiling- repair
302 Ordinance	5-20-1988	I	electrical- inadequate
302 Ordinance	5-20-1988	I	infestation- vermin
302 Ordinance	5-20-1988	I	lead paint
304 Ordinance	5-20-1988	I	fixtures- inadequate wiring
304 Ordinance	5-20-1988	I	water heater- shut off valve
304 Ordinance	5-20-1988	I	windows- repair (cracked)
304 Ordinance	5-20-1988	I	screen door- replace
304 Ordinance	5-20-1988	I	toilet leaks
304 Ordinance	5-20-1988	I	weathertight
304 Ordinance	5-20-1988	I	ceiling- repair
304 Ordinance	5-20-1988	I	lead paint
304 Ordinance	5-20-1988	I	electrical- inadequate
304 Ordinance	5-20-1988	I	infestation- vermin
306 Ordinance	4-20-1988	I	blow down leg
306 Ordinance	4-20-1988	I	gas shut off
306 Ordinance	4-20-1988	I	furnace- improper wiring
306 Ordinance	4-20-1988	I	doors- replace
306 Ordinance	4-20-1988	I	quarterround- replace
306 Ordinance	4-20-1988	I	outlets
306 Ordinance	4-20-1988	I	windows- replace (cracked)
306 Ordinance	4-20-1988	I	roof leaks
306 Ordinance	4-20-1988	E	brick- repair
306 Ordinance	4-20-1988	I	infestation- pests
306 Ordinance	4-20-1988	I	infestation- vermin
300 Ordinance	2-27-1986	I	fire extinguisher- recharge
300 Ordinance	2-27-1986	I	blow down leg
300 Ordinance	2-27-1986	I	gas leak
300 Ordinance	2-27-1986	I	unused gas- cap/valve
300 Ordinance	2-27-1986	I	water heater vent- secure
300 Ordinance	2-27-1986	I	electrical box- cover
300 Ordinance	2-27-1986	I	furnace pipe- secure
300 Ordinance	2-27-1986	I	weatherstripping
300 Ordinance	2-27-1986	I	door latch- repair
300 Ordinance	2-27-1986	I	door glass- replace
300 Ordinance	2-27-1986	I	door- hole
300 Ordinance	2-27-1986	I	ceiling- repair
302 Ordinance	12-13-1985	I	sink drain- repair
306 Ordinance	12-13-1985	I	sink drain- repair
306 Ordinance	12-13-1985	I	walls/ ceilings- clean/paint
304 Ordinance	12-13-1985	I	flooring- repair
304 Ordinance	12-13-1985	I	walls- repair
210 Union	12-18-1996	I	run A/C line
212 Union	12-18-1996	I	kitchen floor- repair/replace
212 Union	12-18-1996	I	lavatory drain- repair
212 Union	12-18-1996	I	dryer line- cap
216 Union	12-18-1996	I	outlet- replace/cover
216 Union	12-18-1996	I	fire extinguisher
216 Union	12-18-1996	E	storm windows
216 Union	12-18-1996	I	smoke detectors

Violation_Table

218 Union	12-18-1996	E	storm windows
208-218 Union	11-26-1996	E	chipped paint
208 Union	9-15-1993	I	light fixtures- repair
208 Union	9-15-1993	I	cracked windows
208 Union	9-15-1993	I	bedroom door-repair
208 Union	9-15-1993	I	secure screen- furnace room
208 Union	9-15-1993	I	shower wall/ plumbing- repair
208 Union	9-15-1993	E	front porch- secure
208 Union	9-15-1993	I	screens- repair
210 Union	9-15-1993	I	dirty
210 Union	9-15-1993	I	ceiling light- repair
210 Union	9-15-1993	E	leaky roof- repair
212 Union	9-15-1993	I	screen- furnace room
212 Union	9-15-1993	I	shade/curtain brackets
214 Union	9-15-1993	I	fire extinguisher- replace
214 Union	9-15-1993	I	hot water- bathroom
214 Union	9-15-1993	E	leaky roof
214 Union	9-15-1993	I	infestation (vermin)
216 Union	9-15-1993	I	fire extinguisher
216 Union	9-15-1993	I	closet rollers- replace
216 Union	9-15-1993	I	cracked windows
208-218 Union	9-10-1993	E	chipped paint
301 Union	6-26-2001	I	tile- repair
301 Union	6-26-2001	I	GFCI- replace
301 Union	7-23-1997	E	chipped paint
301 Union	7-23-1997	E	tires in yard
301 Union	7-23-1997	I	screens- repair
301 Union	7-23-1997	I	light- repair
301 Union	7-23-1997	I	bathroom floor- repair
301 Union	7-23-1997	I	tub walls- repair
303 Union	7-23-1997	I	carpet-stairs (replace)
303 Union	7-23-1997	I	light- repair
305 Union	7-23-1997	I	bathroom floor- repair
305 Union	7-23-1997	I	screens
305 Union	7-23-1997	I	kitchen floor- replace
307 Union	7-23-1997	I	clean- floors/walls
307 Union	7-23-1997	I	paint- walls/ceiling
307 Union	7-23-1997	I	fire extinguisher
307 Union	7-23-1997	I	outlets- repair/replace/secure
307 Union	7-23-1997	I	storm windows
307 Union	7-23-1997	I	smoke detectors
307 Union	7-23-1997	I	bathroom floor- replace
307 Union	7-23-1997	I	outlets- repair/replace
307 Union	7-23-1997	I	floors- clean/repair/replace
301-307 Union	7-3-1997	E	chipped paint
305 Union	8-16-1994	I	carpet on steps- secure
305 Union	8-16-1994	I	toilet valve- repair
307 Union	8-16-1994	I	kitchen ceiling- holes
305-307 Union	8-16-1994	I	hallways- holes
301-307 Union	8-4-1994	E	chipped paint
301-307 Union	11-5-1991	E	chipped paint

Violation_Table

301 Union	10-31-1991	I	window- repair
301 Union	10-31-1991	I	gas lines- replace
301 Union	10-31-1991	I	tub walls- replace
301 Union	10-31-1991	I	loose tiles
303 Union	10-31-1991	I	water heater pipe- replace
303 Union	10-31-1991	I	plumbing- replace (shower)
305 Union	10-31-1991	E	no access
307 Union	10-31-1991	E	window (LR)
307 Union	10-31-1991	E	windows- repair
303 Union	9-25-1990	I	screens
303 Union	9-25-1990	I	water line- remove/replace
303 Union	9-25-1990	I	blow down leg
305 Union	9-25-1990	I	water line- remove/replace
305 Union	9-25-1990	I	breaker box- replace
305 Union	9-25-1990	I	water line- remove/replace
305 Union	9-25-1990	I	blow down leg
301 Union	9-25-1990	I	water line- remove/replace
301-307 Union	9-29-1988	I	paint/repair ceilings/walls
301-307 Union	9-29-1988	I	floor/coverings- replace
301-307 Union	9-29-1988	I	counters- gaps
301-307 Union	9-29-1988	I	closet doors
301-307 Union	9-29-1988	I	tubs- repair
307 Union	9-29-1988	I	lavatory- replace
303 Union	3-22-1989	I	vent hoods
304 Ordinance	12-13-1985	I	walls/ceiling- repair
302 Ordinance	12-13-1985	I	walls/ceiling- repair
302-306 Ordinance	12-13-1985	I	smoke detectors- repair
302 Ordinance	12-13-1985	E	peeling paint
304 Ordinance	12-13-1985	E	peeling paint
300-306 Ordinance	12-13-1985	I	fire extinguisher
300-306 Ordinance	6-20-1983	I	gas valve
300-306 Ordinance	6-20-1983	I	blow down leg
300-306 Ordinance	6-20-1983	I	walls/ceiling- repair
302 Ordinance	6-20-1983	I	weak floor
304 Ordinance	6-20-1983	I	weak floor
300-304 Ordinance	6-20-1983	I	floor covering- replace
300 Ordinance	6-20-1983	E	storm window
306 Ordinance	6-20-1983	I	outlet
300-307 Ordinance	2-19-1980	I	blow down leg
300-307 Ordinance	2-19-1980	I	gas shut off valve
300-307 Ordinance	2-19-1980	I	electric- inadequate
300-307 Ordinance	2-19-1980	I	fire extinguisher
300-307 Ordinance	2-19-1980	I	smoke detector
242 Ordinance	12-2-1983	I	floor- repair
242 Ordinance	12-2-1983	I	floor covering- replace
242 Ordinance	12-2-1983	I	outlet covers
242 Ordinance	12-2-1983	E	water leak- under unit
238 Ordinance	12-2-1983	I	window panes- repair/replace
240 Ordinance	12-2-1983	I	window panes- repair/replace
232 Ordinance	12-2-1983	I	smoke detector
234 Ordinance	12-2-1983	I	smoke detector

Violation_Table

232 Ordinance	12-2-1983	I	fire extinguisher
234 Ordinance	12-2-1983	I	peeling paint
232-242 Ordinance	12-2-1983	I	electrical- inadequate
242 Ordinance	11-15-1983	I	floor- repair (hole)
242 Ordinance	11-15-1983	I	floor covering- replace
242 Ordinance	11-15-1983	I	outlet covers
238 Ordinance	11-15-1983	I	window panes- replace/ repair
232 Ordinance	11-15-1983	I	window panes- repair/replace
240 Ordinance	11-15-1983	I	window panes- repair/ replace
232-242 Ordinance	11-15-1983	I	smoke detector
232 Ordinance	11-15-1983	I	fire extinguisher
234 Ordinance	11-15-1983	E	chipped paint
242 Ordinance	11-15-1983	E	water leak- under unit
222-228 Ordinance	1-7-2005	E	chipped paint
222 Ordinance	1-14-2005	I	smoke detectors- repair
226 Ordinance	1-14-2005	I	smoke detectors- repair
222 Ordinance	2-23-2001	E	outlet- secure
222 Ordinance	2-23-2001	I	cabinets- repair
222 Ordinance	2-23-2001	I	floor covering- replace
224 Ordinance	2-23-2001	E	light- secure/repair
224 Ordinance	2-23-2001	I	smoke detector- repair
226 Ordinance	2-23-2001	I	doors- repair
228 Ordinance	2-23-2001	I	fire extinguisher
228 Ordinance	2-23-2001	I	dirty/cluttered
222-228 Ordinance	1-23-2001	E	chipped paint
222-228 Ordinance	4-30-1998	E	chipped paint
222 Ordinance	9-5-1995	E	junk
222-228 Ordinance	1-29-1990	I	peeling paint
222-228 Ordinance	1-29-1990	I	flooring- repair
222-228 Ordinance	1-29-1990	I	floor covering- repair/replace
222-228 Ordinance	1-29-1990	E	peeling paint
222-228 Ordinance	1-29-1990	I	doors
222-228 Ordinance	1-29-1990	I	cabinets/counters- replace
222-228 Ordinance	1-29-1990	I	walls- replace
222-228 Ordinance	1-29-1990	I	hand rails
222-228 Ordinance	1-29-1990	E	roof- replace
222-228 Ordinance	1-29-1990	E	roof overhangs- repair
222-228 Ordinance	1-29-1990	E	tile block- repair/ replace
222-228 Ordinance	1-29-1990	E	stoops/sidewalks/steps- repair/ remove
222-228 Ordinance	1-29-1990	E	porch overhangs- replace/repair
222-228 Ordinance	1-29-1990	E	soffits/facia/window trim- repair/paint
222-228 Ordinance	1-29-1990	E	storage shed- remove
222-228 Ordinance	1-29-1990	E	antenna/towers- remove
222-228 Ordinance	1-29-1990	E	basement- weatherproof
222-228 Ordinance	1-29-1990	E	cable/tv hookups- clean up
222 Ordinance	3-31-1992	I	outlet- secure wire
222 Ordinance	3-31-1992		electrical panel- label
222 Ordinance	3-31-1992		gaps in tiled floor
222 Ordinance	3-31-1992		weather seal
222 Ordinance	3-31-1992		bathroom exhaust fan- hook up
222 Ordinance	3-31-1992		door latch

Violation_Table

222-228 Ordinance	3-31-1992	E	tile/ tuckpointing repair
222-228 Ordinance	3-31-1992	E	exterior lights
222-228 Ordinance	3-31-1992	E	paint/ plaster
222-228 Ordinance	3-31-1992	E	lavatories- hook up/finish plumbing
222-228 Ordinance	3-31-1992	E	CATV boxes
222-228 Ordinance	3-31-1992	E	handrails/guardrails
222-228 Ordinance	3-31-1992	I	smoke detectors- replace
222-228 Ordinance	3-31-1992	I	outlets- replace
222-228 Ordinance	3-31-1992	I	loose tiles
222-228 Ordinance	3-31-1992	I	loose walls
222-228 Ordinance	3-31-1992	I	floors- secure
222-228 Ordinance	3-31-1992	I	screens/storm windows- replace
222-228 Ordinance	3-31-1992	I	cartridge fuses in box- replace
222-228 Ordinance	3-31-1992	I	fire extinguisher
222-228 Ordinance	3-31-1992	I	dirty/cluttered
224 Ordinance	3-31-1992	I	doors- replace
224 Ordinance	3-31-1992	I	weathertight
224 Ordinance	3-31-1992	I	loose carpet- stairs
224 Ordinance	3-31-1992	I	overcrowded
222 Ordinance	3-31-1992	I	cracked windows
226 Ordinance	3-31-1992	I	doors- replace
226 Ordinance	3-31-1992	I	weathertight
226 Ordinance	3-31-1992	I	loose carpet- stairs
226 Ordinance	3-31-1992	I	overcrowded
222 Ordinance	7-21-1989	I	door- replace
222 Ordinance	7-21-1989	I	broken windows
222 Ordinance	7-21-1989	I	loose tiles
224 Ordinance	7-21-1989	I	loose tiles
224 Ordinance	7-21-1989	I	floor covering- replace
224 Ordinance	7-21-1989	I	smoke detector- repair
224 Ordinance	7-21-1989	I	doors- replace
224 Ordinance	7-21-1989	I	overcrowded
226 Ordinance	7-21-1989	I	secure sink
226 Ordinance	7-21-1989	I	gas- shut off valve
226 Ordinance	7-21-1989	I	plumbing- cap
226 Ordinance	7-21-1989	I	smoke detector- repair
228 Ordinance	7-21-1989	I	loose tile
228 Ordinance	7-21-1989	I	shower wall- replace
228 Ordinance	7-21-1989	I	cabinets- replace/repair
222-228 Ordinance	7-21-1989	E	remove dividers
224 Ordinance	7-20-1989	I	tiles loose
224 Ordinance	7-20-1989	I	outlets
224 Ordinance	7-20-1989	I	screens
224 Ordinance	7-20-1989	I	carpet- replace
224 Ordinance	7-20-1989	E	doors- repair/replace
226 Ordinance	7-20-1989	I	walls- secure
226 Ordinance	7-20-1989	I	gas shut off valve
228 Ordinance	7-20-1989	I	tile rotten/loose
228 Ordinance	7-20-1989	I	cabinets- replace/repair
228 Ordinance	7-20-1989	I	shower walls- replace
228 Ordinance	4-22-1988	I	inadequate circuits

Violation_Table

228 Ordinance	4-22-1988	I	water heater- remove PVC
228 Ordinance	4-22-1988	I	outlets
226 Ordinance	4-22-1988	I	PVC- remove
226 Ordinance	4-22-1988	I	electric- inadequate
226 Ordinance	4-22-1988	I	paint peeling
226 Ordinance	4-22-1988	I	junction box- cover
226 Ordinance	4-22-1988	I	gas shut off valve
226 Ordinance	4-22-1988	I	cracked glass
226 Ordinance	4-22-1988	I	water heater- replace gas line
226 Ordinance	4-22-1988	I	smoke detector
226 1/2 Ordinance	4-22-1988	I	electric-inadequate
226 1/2 Ordinance	4-22-1988	I	outlets
226 1/2 Ordinance	4-22-1988	I	cracked windows
226 1/2 Ordinance	4-22-1988	I	plumbing- replace
226 1/2 Ordinance	4-22-1988	I	wiring- replace (inadequate)
226 1/2 Ordinance	4-22-1988	I	infestation- vermin/pests
224 Ordinance	4-22-1988	I	infestation- pests
224 Ordinance	4-22-1988	I	PVC- remove
224 Ordinance	4-22-1988	I	shower- repair
224 Ordinance	4-22-1988	I	broken glass
224 Ordinance	4-22-1988	I	4 plug outlet- remove
224 Ordinance	4-22-1988	I	breakers/circuits replace
224 Ordinance	4-22-1988	I	cracked windows
224 Ordinance	4-22-1988	I	holes in walls
224 Ordinance	4-22-1988	I	outlets
222 Ordinance	4-22-1988	I	PVC- water heater
222 Ordinance	4-22-1988	I	water heater- PVC
222 Ordinance	4-22-1988	I	circuit/breakers- replace (inadequate)
222 Ordinance	4-22-1988	E	peeling paint
228 Ordinance	4-20-1988	I	circuits
228 Ordinance	4-20-1988	I	outlets
226 Ordinance	4-20-1988	I	PVC blow down- remove
226 Ordinance	4-20-1988	I	gas shut off valve
226 Ordinance	4-20-1988	I	cracked glass
226 Ordinance	4-20-1988	I	furnace overfused
226 Ordinance	4-20-1988	I	lead paint
224 Ordinance	4-20-1988	I	infestation- pests
224 Ordinance	4-20-1988	I	PVC blow down- remove
224 Ordinance	4-20-1988	I	shower- repair
224 Ordinance	4-20-1988	I	windows- holes/cracked
224 Ordinance	4-20-1988	I	outlets- remove/replace
224 Ordinance	4-20-1988	I	walls- hole
226 1/2 Ordinance	4-20-1988	I	cracked windows
226 1/2 Ordinance	4-20-1988	I	electrical- inadequate
226 Ordinance	4-20-1988	I	electrical- inadequate
226 Ordinance	4-20-1988	I	wiring improper
226 Ordinance	4-20-1988	I	infestation- pests
226 Ordinance	4-20-1988	I	infestation- vermin
224 Ordinance	12-4-1987	I	outlets
224 Ordinance	12-4-1987	I	smoke detector- repair
224 Ordinance	12-4-1987	I	blow down leg- replace

Violation_Table

224 Ordinance	12-4-1987	I	water heater vent- secure
224 Ordinance	12-4-1987	I	furnace wire- conduit
226 Ordinance	6-2-1987	I	unsafe wiring
226 Ordinance	6-2-1987	I	one exit
228 Ordinance	1-8-1985	I	infestation- pests
212 Ordinance	1-14-2005	I	door locks- replace/repair
210-216 Ordinance	2-14-2002	E	chipped paint
210 Ordinance	1-29-2002	I	GFCI- wont trip
212 Ordinance	1-29-2002	I	smoke detectors- hardwire
212 Ordinance	1-29-2002	I	storm doors
214 Ordinance	1-29-2002	I	GFCI- wont trip
210-218 Ordinance	3-1-1999	E	chipped paint
210-218 Ordinance	5-23-1986	E	chipped paint
209-219 Ordinance	11-15-1983	I	subfloor- repair
217 Ordinance*	11-15-1983	I	smoke detector
217 Ordinance*	11-15-1983	I	fire extinguisher
219 Ordinance*	11-15-1983	I	fire extinguisher
219 Ordinance*	11-15-1983	I	smoke detector
239 Ordinance*	5-19-1986	E	cars in yard
239 Ordinance*	5-19-1986	E	junk/weeds/grass
235 Ordinance*	7-21-1983	I	screens-replace/repair
235 Ordinance*	7-21-1983	I	peeling paint
237 Ordinance*	12-8-1983	I	water heaters- gas shut off valve
239 Ordinance*	12-8-1983	I	water heaters- gas shut off valve
241 Ordinance*	12-8-1983	I	water heaters- gas shut off valve
243 Ordinance*	12-8-1983	I	water heaters- gas shut off valve
237 Ordinance*	12-8-1983	I	furnace- gas shut off valve
239 Ordinance*	12-8-1983	I	furnace- gas shut off valve
241 Ordinance*	12-8-1983	I	furnace- gas shut off valve
243 Ordinance*	12-8-1983	I	furnace- gas shut off valve
235 Ordinance*	12-8-1983	I	broken windows
237 Ordinance*	12-8-1983	I	broken windows
239 Ordinance*	12-8-1983	I	broken windows
241 Ordinance*	12-8-1983	I	broken windows
233-237 Ordinance*	12-8-1983	I	fire extinguisher
243 Ordinance*	12-8-1983	I	fire extinguisher
233-243 Ordinance*	12-8-1983	I	smoke detectors
239 Ordinance*	12-8-1983	I	peeling paint
235 Ordinance*	12-8-1983	I	peeling paint
233-243 Ordinance*	12-8-1983	I	electrical- replace
237-243 Ordinance*	11-15-1993	I	blow down leg
237-243 Ordinance*	11-15-1993	I	gas valve
233-243 Ordinance*	11-15-1993	I	broken windows
233-243 Ordinance*	11-15-1993	I	smoke detectors
233-243 Ordinance*	11-15-1993	I	fire extinguishers
239 Ordinance*	11-15-1993	I	peeling paint
235 Ordinance*	11-15-1993	I	peeling paint
301-307 Ordinance*	9-13-1989	E	chipped paint
303 Ordinance*	3-16-1989	I	barely meets code
307 Ordinance*	3-16-1989	I	barely meets code
307 Ordinance*	1-16-1989	I	no water pressure

Violation_Table

307 Ordinance*	1-16-1989	I	unsafe facilities (roof,electric,water, etc)
301 Ordinance*	1-16-1989	I	unsafe facilities
301 Ordinance*	1-16-1989	I	fire extinguisher
301 Ordinance*	1-16-1989	I	smoke detectors
301 Ordinance*	1-16-1989	I	peeling paint
301 Ordinance*	1-16-1989	E	leaky roof
301 Ordinance*	1-16-1989	I	weatherstripping
301 Ordinance*	1-16-1989	I	ceilings/walls- repair
301 Ordinance*	1-16-1989	I	electrical- inadequate
301 Ordinance*	1-16-1989	I	breakers- oversized
301 Ordinance*	1-16-1989	I	wiring- improper
301 Ordinance*	1-16-1989	I	fixtures- unsafe
301 Ordinance*	1-16-1989	I	gas line- improper
301 Ordinance*	1-16-1989	I	infestation- pests
301 Ordinance*	1-16-1989	I	dirty/cluttered
305 Ordinance*	1-16-1989	I	fire extinguisher
305 Ordinance*	1-16-1989	I	smoke detectors
305 Ordinance*	1-16-1989	I	peeling paint
305 Ordinance*	1-16-1989	I	roof leaks
305 Ordinance*	1-16-1989	I	weatherstripping
305 Ordinance*	1-16-1989	I	ceiling/walls- repair
305 Ordinance*	1-16-1989	I	screens/storms
305 Ordinance*	1-16-1989	I	electric- inadequate
305 Ordinance*	1-16-1989	I	breakers- oversized
305 Ordinance*	1-16-1989	I	wiring- improper
305 Ordinance*	1-16-1989	I	fixtures- unsafe
305 Ordinance*	1-16-1989	I	gas line- improper
305 Ordinance*	1-16-1989	I	infestation- pests
305 Ordinance*	1-16-1989	I	dirty/cluttered
301 Ordinance*	1-16-1989	I	screens
307 Ordinance*	1-16-1989	I	weatherstripping
307 Ordinance*	1-16-1989	I	screens/storms
307 Ordinance*	1-16-1989	I	infestation- pests
307 Ordinance*	1-16-1989	I	loose floor boards
301-307 Ordinance*	10-4-1988	I	facilities unsafe (electric,roof,water,ceilings)
303 Ordinance*	10-4-1988	I	water heater- unsafe
303 Ordinance*	10-4-1988	I	fire extinguisher
303 Ordinance*	10-4-1988	I	smoke detectors
303 Ordinance*	10-4-1988	I	peeling paint
303 Ordinance*	10-4-1988	I	electrical- inadequate
303 Ordinance*	10-4-1988	I	breakers- oversized
303 Ordinance*	10-4-1988	I	fixtures unsafe
303 Ordinance*	10-4-1988	I	gas line- improper
307 Ordinance*	10-4-1988	I	water heater- unsafe
307 Ordinance*	10-4-1988	I	steps- unsafe
307 Ordinance*	10-4-1988	I	weatherproofing
307 Ordinance*	10-4-1988	I	gas line- improper
307 Ordinance*	10-4-1988	E	peeling paint
307 Ordinance*	10-4-1988	I	peeling paint
307 Ordinance*	10-4-1988	E	soffits/roof- rotten
307 Ordinance*	10-4-1988	I	screens/storms

Violation_Table

307 Ordinance*	10-4-1988	I	electricall- inadequate
307 Ordinance*	10-4-1988	I	infestation- pests
307 Ordinance*	10-4-1988	I	fire extinguisher
307 Ordinance*	10-4-1988	I	improper flooring
303 Ordinance*	4-25-1988	I	ceiling- repair
303 Ordinance*	4-25-1988	I	fixtures- replace/repair
303 Ordinance*	4-25-1988	I	water heater gas line- replace
303 Ordinance*	4-25-1988	I	blow down leg
303 Ordinance*	4-25-1988	I	furnace wiring- improper
303 Ordinance*	4-25-1988	I	peeling paint
303 Ordinance*	4-25-1988	I	weatherstripping
301-307 Ordinance*	4-25-1988	I	electric- inadequate
301-307 Ordinance*	4-25-1988	I	roof leaks
301-307 Ordinance*	4-25-1988	I	breakers- improper size
301-307 Ordinance*	4-25-1988	E	soffits rotted
301-307 Ordinance*	4-25-1988	I	peeling paint
301-307 Ordinance*	4-25-1988	I	weather proofing
301-307 Ordinance*	4-25-1988	I	fire extinguishers
301-307 Ordinance*	4-25-1988	I	smoke detectors
307 Ordinance*	4-25-1988	I	no water pressure
307 Ordinance*	4-25-1988	I	blow down leg
307 Ordinance*	4-25-1988	I	water heater- pressure relieve valve
307 Ordinance*	4-25-1988	I	holes in ciling
307 Ordinance*	4-25-1988	I	water heater- shut off valve
307 Ordinance*	4-25-1988	I	floors- repair/replace
307 Ordinance*	4-25-1988	I	guardrail on stairs
307 Ordinance*	4-25-1988	I	smoke detector- repair
307 Ordinance*	4-25-1988	I	electrical- rewire
301-307 Ordinance*	10-4-1988	I	facilities unsafe- (electric,roof, water,heat,etc)
301-307 Ordinance*	10-4-1988	E	soffits rotten
301-307 Ordinance*	10-4-1988	E	leaky roof
301-307 Ordinance*	10-4-1988	E	peeling paint
301-307 Ordinance*	10-4-1988	I	weather proofing
301-307 Ordinance*	10-4-1988	I	walls/ceilings- repair
301-307 Ordinance*	10-4-1988	E	rain water drainage
301-307 Ordinance*	10-4-1988	E	unprotected wood
301-307 Ordinance*	10-4-1988	I	electrical- inadequate
301-307 Ordinance*	10-4-1988	I	screens/storms
303 Ordinance*	10-4-1988	I	water heater- unsafe
303 Ordinance*	10-4-1988	I	smoke detectors
303 Ordinance*	10-4-1988	I	peeling paint
303 Ordinance*	10-4-1988	I	fire extinguisher
303 Ordinance*	10-4-1988	I	oversized breakers
303 Ordinance*	10-4-1988	I	wiring- improper
303 Ordinance*	10-4-1988	I	unsafe fixtures
303 Ordinance*	10-4-1988	I	gas lines- improper
301 Ordinance*	10-4-1988	I	wiring- improper
301 Ordinance*	10-4-1988	I	unsafe fixtures
307 Ordinance*	10-4-1988	I	water heater- unsafe
307 Ordinance*	10-4-1988	I	steps- unsafe
307 Ordinance*	10-4-1988	I	fire extinguisher

Violation_Table

307 Ordinance*	10-4-1988	I	smoke detectors
307 Ordinance*	10-4-1988	I	gas lines- improper
307 Ordinance*	6-28-1988	I	no guardrail
307 Ordinance*	6-28-1988	I	water heater- vent
307 Ordinance*	6-28-1988	I	water heater- pressure valve
307 Ordinance*	6-28-1988	I	blow down leg- repair
301 Ordinance*	10-4-1988	I	oversized breakers
307 Ordinance*	6-28-1988	I	gas shut off valve
307 Ordinance*	6-28-1988	I	outlets- rewire
307 Ordinance*	6-28-1988	I	floors- replace/repair
307 Ordinance*	6-28-1988	I	ceiling-holes
307 Ordinance*	6-28-1988	I	smoke detector- repair
307 Ordinance*	6-28-1988	I	screens/storms
307 Ordinance*	4-20-1988	I	ceilings- repair
307 Ordinance*	4-20-1988	I	wiring- replace
307 Ordinance*	4-20-1988	I	peeling paint
307 Ordinance*	4-20-1988	I	weather tight
307 Ordinance*	4-20-1988	E	leaky roof
307 Ordinance*	4-20-1988	I	fire extinguisher
307 Ordinance*	4-20-1988	I	infestation- pests
307 Ordinance*	4-20-1988	I	smoke detector
301 Ordinance*	4-20-1988	I	screens- repair/replace
301 Ordinance*	4-20-1988	I	electrical wiring- replace
301 Ordinance*	4-20-1988	I	water heater- replace
305 Ordinance*	4-20-1988	I	broken glass
305 Ordinance*	4-20-1988	I	lavatory leak
305 Ordinance*	4-20-1988	I	light fixtures- inadequate
307 Ordinance*	4-20-1988	I	renovate
301-307 Ordinance*	4-20-1988	I	electric- replace
301-307 Ordinance*	4-20-1988	I	outlets
305 Ordinance*	6-15-1983	I	infestation-pests/vermin
305 Ordinance*	6-15-1983	I	broken glass
305 Ordinance*	6-15-1983	I	cabinets- repair
305 Ordinance*	6-15-1983	I	drains leak
3117	8-20-2003	E	storage shed- bad shape
	7-31-2003	E	chipped paint
	8-31-2000	E	peeling paint-windows
3119 Valley	8-31-2000	I	gas line- cap
3117 Valley	8-4-2000	E	chipped paint
3201 Valley	6-3-1997	I	GFCI outlet- replace
3119 Valley	8-20-2003	E	storage shed- bad shape
3119 Valley	7-31-2003	E	chipped paint
3119 Valley	8-31-2000	E	peeling paint-windows
3201 Valley	8-20-2003	E	storage shed- bad shape
3201 Valley	7-31-2003	E	chipped paint
3201 Valley	8-31-2000	E	peeling paint-windows
3203 Valley	8-20-2003	E	storage shed- bad shape
3203 Valley	7-31-2003	E	chipped paint
3203 Valley	8-31-2000	E	peeling paint-windows
3119 Valley	8-4-2000	E	chipped paint
3201 Valley	8-4-2000	E	chipped paint

Violation_Table

3203 Valey	8-4-2000	E	chipped paint
3201 Valley	6-3-1997	I	gas line- shut off valve
3201 Valley	6-3-1997		smoke detectors
3201 Valley	6-3-1997		fire extinguisher
3203 Valley	6-3-1997		gas line- shut off valve
3203 Valley	6-3-1997		cover junction box
3203 Valley	6-3-1997		smoke detectors
3203 Valley	6-3-1997		fire extinguisher
3203 Valley	6-3-1997	E	overhang- repair
3203 Valley	6-3-1997	E	paint- replace
3203 Valley	6-3-1997	E	storms/screens
3117 Valley	6-3-1997	I	fire extinguisher
3117 Valley	6-3-1997	E	chipped paint
3119 Valley	6-3-1997	E	chipped paint
3201 Valley	6-3-1997	E	chipped paint
3203 Valley	6-3-1997	E	chipped paint
180 N Roosevelt	7-17-2005	E	chipped paint
180 N Roosevelt	8-3-2005	I	smoke detector- repair
180 N Roosevelt	8-3-2005	I	doorlocks- replace
180 N Roosevelt	8-3-2005	E	chipped paint- windows
180 N Roosevelt	8-3-2005	E	weatherstripping
180 N Roosevelt	8-3-2005	E	down spout- repair
180 N Roosevelt	8-3-2005	E	screens
180 N Roosevelt	8-3-2005	I	outlets- secure
180 N Roosevelt	8-9-2000	E	chipped paint
180 N Roosevelt	4-1-1991	E	chipped paint
180 N Roosevelt	4-1-1991	I	fire extinguisher
180 N Roosevelt	4-1-1991	I	blow down leg
180 N Roosevelt	2-21-1985	I	fire extinguisher
180 N Roosevelt	2-21-1985	I	smoke detector
180 N Roosevelt	2-21-1985	I	gas valve
180 N Roosevelt	2-21-1985	I	blow down leg
218 N Roosevelt	3-30-2004	E	fence- remove
218 N Roosevelt	3-30-2004	E	gutters/down spouts
218 N Roosevelt	3-30-2004	E	paint- repair
218 N Roosevelt	3-30-2004	E	weather stripping
218 N Roosevelt	3-30-2004	E	screens
218 N Roosevelt	11-27-2002	E	chipped paint
218 N Roosevelt	11-6-2001	E	misc. junk/ garbage in yard
218 N Roosevelt	11-6-2001	E	unsafe containment
218 N Roosevelt	4-6-2001	E	abandoned vehicle- trash in
218 N Roosevelt	4-13-1999	E	misc. junk in yard
218 N Roosevelt	7-14-1998	E	misc. junk/ trash
218 N Roosevelt	7-10-1998	E	misc. junk/ trash
218 N Roosevelt	9-17-1997	E	weeds/grass
218 N Roosevelt	9-17-1997	E	garage- clean
218 N Roosevelt	9-17-1997	E	screens
218 N Roosevelt	9-17-1997	I	fire extinguisher
218 N Roosevelt	9-17-1997	I	gas line- plug/cap
218 N Roosevelt	9-17-1997	I	electrical splice- remove
218 N Roosevelt	9-17-1997	I	smoke detectors- repair

Violation_Table

218 N Roosevelt	9-17-1997	I	too cluttered for inspection
218 N Roosevelt	9-10-1997	E	chipped paint
218 N Roosevelt	10-13-1992	I	blow down leg
218 N Roosevelt	10-13-1992	I	smoke detectors
218 N Roosevelt	10-13-1992	I	cracked windows/glass
218 N Roosevelt	10-13-1992	I	electrical panel- no access
218 N Roosevelt	10-13-1992	I	unsafe electric
218 N Roosevelt	10-13-1992	I	gas line- improper
218 N Roosevelt	10-13-1992	I	furnace-unsafe
218 N Roosevelt	10-13-1992	I	smoke detector
218 N Roosevelt	10-8-1992	I	gas line- replace
218 N Roosevelt	10-8-1992	I	blow down leg
218 N Roosevelt	10-8-1992	I	cracked windows
218 N Roosevelt	10-8-1992	I	wiring- unsafe
218 N Roosevelt	10-8-1992	I	electrical box- no access
222 N Roosevelt	5-25-2004	E	chipped paint
222 N Roosevelt	7-12-1999	E	chipped paint
222 N Roosevelt	8-2-1994	I	water heater- air deflector
222 N Roosevelt	7-19-1994	E	chipped paint
222 N Roosevelt	8-9-1989	I	handrail
222 N Roosevelt	8-9-1989	I	gas line- replace
222 N Roosevelt	8-9-1989	I	fuses- replace
222 N Roosevelt	6-14-1984	I	fire extinguisher- replace
226-228 N Roosevelt	5-25-2004	E	chipped paint
226 N Roosevelt	6-15-1999	I	smoke detector- repair/replace
226 N Roosevelt	6-15-1999	I	fire extinguisher
226 N Roosevelt	6-15-1999	I	upgrade electrical
228 N Roosevelt	6-15-1999	I	broken windows
228 N Roosevelt	6-15-1999	I	upgrade electrical
226 N Roosevelt	6-15-1999	I	smoke detector- repair
226 N Roosevelt	6-15-1999	I	fire extinguisher
228 N Roosevelt	6-15-1999	I	broken windows
226-228 N Roosevelt	6-2-1999	E	chipped paint
226-228 N Roosevelt	8-2-1999	E	peeling paint
226-228 N Roosevelt	8-2-1999	E	gutters/ downspouts- replace/repair
226-228 N Roosevelt	8-2-1999	E	windows- locks
226-228 N Roosevelt	8-2-1999	I	broken windows
226-228 N Roosevelt	8-2-1999	I	storms/ screens
226-228 N Roosevelt	8-2-1999	I	weather tight
226-228 N Roosevelt	6-21-1994	E	chipped paint
226 N Roosevelt	8-9-1989	I	electric- improper
232-234 N Roosevelt	10-10-1998	I	smoke detector- replace
232-234 N Roosevelt	9-8-1993	E	chipped paint
232 N Roosevelt	8-9-1989	I	more circuits
232 N Roosevelt	5-6-1988	I	screens
232 N Roosevelt	5-6-1988	I	ceilings- repair/replace/paint
232 N Roosevelt	5-6-1988	I	walls- repair/paint
232 N Roosevelt	5-6-1988	I	floors- repair
232 N Roosevelt	5-6-1988	I	water heater- replace
232 N Roosevelt	5-6-1988	I	furnace- gas shut off valve
232 N Roosevelt	5-6-1988	I	enclosure- furnace/water heater

Violation_Table

232 N Roosevelt	5-6-1988	I	lavatory- replace
232 N Roosevelt	5-6-1988	I	doors- replace
232 N Roosevelt	5-6-1988	I	electric- rewire
232 N Roosevelt	5-6-1988	E	paint- replace/repair
232 N Roosevelt	5-6-1988	E	roof covering- replace
232 N Roosevelt	5-6-1988	E	overhangs- replace
232 N Roosevelt	5-6-1988	E	gutters/downspouts
234 N Roosevelt	5-6-1988	I	water heater/furnace- enclosure
234 N Roosevelt	5-6-1988	I	ceilings- repair/replace/paint
234 N Roosevelt	5-6-1988	I	walls- repair
234 N Roosevelt	5-6-1988	I	floors- repair/replace
234 N Roosevelt	5-6-1988	I	water heater- replace
234 N Roosevelt	5-6-1988	I	furnace- gas shut off valve
234 N Roosevelt	5-6-1988	I	lavatory- replace
232 N Roosevelt	5-6-1988	I	outlets
238-240 N Roosevelt	5-28-2005	E	chipped paint
238 N Roosevelt	8-2-2005	I	smoke detector- repair
238-240 N Roosevelt	6-5-2000	E	peeling paint- windows
238-240 N Roosevelt	6-5-2000	E	romex- remove
238 N Roosevelt	6-5-2000	I	reduce fuses
238 N Roosevelt	6-5-2000	I	broken windows
240 N Roosevelt	6-5-2000	I	broken windows
240 N Roosevelt	6-5-2000	I	smoke detector- repair
3010-3012 Colombia	5-30-2000	E	chipped paint
238-240 N Roosevelt	8-16-1995	I	ceiling- repair
238-240 N Roosevelt	8-16-1995	E	chipped paint
240 N Roosevelt	9-26-1994	I	windows nailed shut
240 N Roosevelt	9-26-1994	I	bad outlets
240 N Roosevelt	9-26-1994	I	gas leak
240 N Roosevelt	9-26-1994	I	reversed water lines- repair
240 N Roosevelt	9-26-1994	I	windows- broken/missing/cracked
240 N Roosevelt	9-26-1994	I	weathertight
238 N Roosevelt	3-7-1994	I	mold on walls
240 N Roosevelt	1-22-1991	I	water heater- change gas line
240 N Roosevelt	1-22-1991	I	cracked windows
240 N Roosevelt	1-22-1991	I	outlets
240 N Roosevelt	1-22-1991	I	reduce fuses
240 N Roosevelt	1-22-1991	I	outlets
240 N Roosevelt	1-22-1991	I	fire extinguisher
300-302 N Roosevelt	5-27-2005	E	chipped paint
300-302 N Roosevelt	5-19-2000	E	chipped paint
300-302 N Roosevelt	8-10-1995	E	chipped paint
300-302 N Roosevelt	1-22-1991	E	chipped paint
300 N Roosevelt	1-22-1991	I	fire extinguisher
302 N Roosevelt	1-22-1991	I	reduce fuses
302 N Roosevelt	1-22-1991	I	outlets
302 N Roosevelt	1-22-1991	I	smoke detector
310 N Roosevelt	6-2-2005	E	chipped paint
310 N Roosevelt	5-20-2000	E	chipped paint
310 N Roosevelt	8-16-1995	E	screens- repair/replace
310 N Roosevelt	5-28-1991	E	roof- replace

Violation_Table

310 N Roosevelt	5-28-1991	E	gutters/down spouts- replace
310 N Roosevelt	5-28-1991	E	junk/ inoperable vehicles
310 N Roosevelt	5-28-1991	E	fence- repair/ replace
310 N Roosevelt	5-28-1991	E	sidewalk
310 N Roosevelt	5-28-1991	E	carpet on steps-remove/replace
310 N Roosevelt	5-28-1991	E	porch overhangs- repair/replace
310 N Roosevelt	5-28-1991	E	windows- locks
310 N Roosevelt	5-28-1991	E	weather stripping
310 N Roosevelt	5-28-1991	E	peeling paint
310 N Roosevelt	5-28-1991	E	crawlspace- insulat/ ventilate
314 N Roosevelt	5-12-2000	E	abandoned vehicle
314 N Roosevelt	6-8-2000	E	grass/weeds/brush
314 N Roosevelt	12-3-1982	I	gas shut off valve
314 N Roosevelt	12-3-1982	I	blow down leg
314 N Roosevelt	12-3-1982	I	broken windows
2911-2913 Columbia	12-10-1986	I	ceiling- repair/replace
2911-2913 Columbia	12-10-1986	I	walls- repair
2911-2913 Columbia	12-10-1986	I	doors- repair replace
2911-2913 Columbia	12-10-1986	I	furnace- replace
2911-2913 Columbia	12-10-1986	I	plumbing- unused-sealed
2911-2913 Columbia	12-10-1986	I	wiring- replace
2911-2913 Columbia	12-10-1986	E	storm- doors/windows
2911 Columbia	8-30-1988	E	storm-doors/windows- repair/replace
2911 Columbia	8-30-1988	I	electrical junction box- uncovered
2911 Columbia	8-30-1988	E	junk/inoperable equipment
2917 Columbia	12-7-1999	E	junk
2917 Columbia	5-11-1988	E	trash/misc.junk/refuse/dog feces
2917 Columbia	5-7-1998	I	over occupancy
2917 Columbia	3-16-1994	I	romex- remove
2917 Columbia	3-16-1994	I	broken windows
2917 Columbia	3-16-1994	I	water heater-water lines- replace
3005 Columbia	11-4-2001	E	chipped paint
3005 Columbia	5-14-1998	E	grass
3005 Columbia	5-14-1998	I	outlet cover
3005 Columbia	11-6-1996	I	hardwire- replace
3005 Columbia	11-6-1996	E	chipped paint
3009 Columbia	3-6-2006	I	poor living conditions
3009 Columbia	3-6-2006	I	infestation- pests
3011 Columbia	5-14-1998	E	grass
3011 Columbia	6-25-2002	I	gas leak in furnace
3011 Columbia	6-25-2002	I	furnace- pilot lite goes out
3011 Columbia	6-25-2002	E	chimney- cap
3011 Columbia	6-25-2002	I	lafatory- doesn't drain
3011 Columbia	5-22-2001	E	high grass
3009-3011 Columbia	6-21-1994	E	chipped paint
3009-3011 Columbia	8-9-1989	I	fire extinguisher- repair
3009-3011 Columbia	11-30-1997	I	walls- repair/paint
3009-3011 Columbia	11-30-1997	I	ceilings- repair/paint
3009-3011 Columbia	11-30-1997	I	flooring/subfloor- replace
3009-3011 Columbia	11-30-1997	I	lavatory- repair/replace
3009-3011 Columbia	11-30-1997	I	smoke detectors

Violation_Table

3009-3011 Columbia	11-30-1997	I	weather stripping
3009-3011 Columbia	11-30-1997	I	windows- replace
3009-3011 Columbia	11-30-1997	I	windows- locks
3009-3011 Columbia	11-30-1997	I	attic ventilation
3009-3011 Columbia	11-30-1997	I	storms/screens
3009-3011 Columbia	11-30-1997	I	peeling paint
3009-3011 Columbia	11-30-1997	E	peeling paint
3009-3011 Columbia	11-30-1997	I	fire extinguisher
3009-3011 Columbia	11-30-1997	I	furnace- replace
3009 Columbia	11-30-1997	I	water heater- replace
3009-3011 Columbia	11-30-1997	I	electrical panels- label
3009 Columbia	11-30-1997	E	trash pit
3009 Columbia	11-30-1997	E	roof- replace
3204-3206 Market	12-26-2002	E	chipped paint
3204 Market	12-8-1997	E	storm door- closures
3204 Market	12-8-1997	I	windows/doors- repair/ replace
3204 Market	12-8-1997	I	screens
3204 Market	12-8-1997	I	smoke detectors- repair
3204 Market	12-8-1997	I	floors- replace
3206 Market	12-8-1997	I	window locks
3204 Market	12-8-1997	E	screens- repair/replace
3204 Market	12-8-1997	I	smoke detector- repair
3204 Market	12-8-1997	I	storm door- closures
3204-3206 Market	11-21-1997	E	chipped paint
3204 Market	1-27-1993	E	storm windows
3204 Market	1-27-1993	I	cover outlets
3206 Market	1-27-1993	I	cracked windows
3204-3206 Market	unknown	I	window locks
3204-3206 Market	unknown	I	attic vent
3204-3206 Market	unknown	E	storms/screens
3204-3206 Market	unknown	E	windows- scrape/repair
3204-3206 Market	unknown	I	fixtures- replace
3204-3206 Market	unknown	I	walls- repair
3204-3206 Market	unknown	I	lavatory plumbing- replace/repair
3204-3206 Market	unknown	E	siding- repair/scrape/paint
3204-3206 Market	unknown	E	sidewalk- repair
3204-3206 Market	unknown	E	downspouts/splash blocks
3204-3206 Market	unknown	E	roof louvers
3204-3206 Market	unknown	I	electrical- rewire
3204-3206 Market	unknown	I	floor- insulate
3204 Market	unknown	I	water heater- enclose
3204 Market	unknown	I	water heater- replace valve
3204 Market	unknown	I	gas shut off valves
3204 Market	unknown	I	walls- repair
3204 Market	unknown	I	broken windows
3204 Market	unknown	I	shower stall- replace
3204 Market	unknown	I	plumbing- replace (kitchen)
3204 Market	unknown	I	light switches
3204 Market	unknown	I	smoke detectors
3204-3206 Market	1-21-1980	I	blow down leg
3204-3206 Market	1-21-1980	I	fire extinguishers

Violation_Table

3204-3206 Market	1-21-1980	I	smoke detectors
3206 Market	1-21-1980	I	furnace-gas line- replace
3114 Market	9-26-2000	E	tires/furniture in yard
3114 Market	11-15-1993	I	mold-floors/joists
3114 Market	11-15-1993	E	rotted wood- windows
3114 Market	11-15-1993	I	rotted wood
3114 Market	11-15-1993	I	walls- repair
3114 Market	11-15-1993	I	weather tight
3114 Market	11-15-1993	E	mold- round building
3114 Market	11-15-1993	I	mold- all over
3114 Market	11-15-1993	I	attic- abestas
3114 Market	11-15-1993	I	poison noticed
3114 Market	11-15-1993	I	worms
3114 Market	11-15-1993	I	fire extinguisher
3114 Market	11-14-1990	I	water heater- gas shut off valve- repair
3104-3106 Market	11-29-2002	E	chipped paint
3104 Market	12-10-1997	I	window locks
3104 Market	12-10-1997	I	GFCI eceptacle- replace
3104 Market	12-4-1987	I	electric- no main disconnect
3104 Market	12-4-1987	I	peeling paint
3104 Market	12-4-1987	I	water heater- no union on gas line
3104 Market	12-4-1987	I	cracked windows
3104 Market	12-4-1987	I	fire extinguisher
3106 Market	12-4-1987	I	outlet covers
3106 Market	12-4-1987	I	blow down leg
3106 Market	12-4-1987	I	union after shut off
3106 Market	12-4-1987	I	cracked windows
3106 Market	12-4-1987	I	fire extinguisher
3104-3106 Market	12-4-1987	E	rotted wood
3104-3106 Market	12-4-1987	E	siding- repair
3104 Market	2-19-1985	I	cracked windows
3104 Market	2-19-1985	I	walls- repair/paint
3104 Market	2-19-1985	I	water heater- shut off valve
3104 Market	2-19-1985	I	blow down leg- replace
3104 Market	2-19-1985	I	water heater- water valve
3010 Market	8-11-2005	I	no water
3010 Market	8-11-2005	I	gas shut off valve
3010 Market	8-11-2005	I	fire extinguisher
3008 Market	8-11-2005	I	fire extinguisher
3008-3010 Market	8-11-2005	E	peeling paint (shed)
3010 Market	7-17-2000	I	switches- replace
3008-3010 Market	7-8-2000	E	chipped paint
3008-3010 Market	8-1-1995	I	secure cabinets
3008-3010 Market	8-1-1995	I	smoke detectors- repair
3008-3010 Market	8-1-1995	E	chipped paint
3010 Market	2-28-1991	I	storm door- repair/replace
3010 Market	2-28-1991	I	handrail
3010 Market	2-28-1991	I	fire extinguisher
3010 Market	2-28-1991	I	mold
3008-3010 Market	8-19-1991	E	chipped paint
3004 Market	10-12-2005	I	broken windows

Violation_Table

3004-3006 Market	9-21-2005	E	chipped paint
3004-3006 Market	9-14-2000	E	chipped paint
3004-3006 Market	10-25-1995	E	chipped paint
3004-3006 Market	10-23-1990	I	outlets
3004-3006 Market	10-23-1990	I	furnace-gas line- replace
3004-3006 Market	10-23-1990	I	water heater- gasoline- replace
3004-3006 Market	10-23-1990	I	gas shut off valves
3000-3002 Market	7-26-2004	E	chipped paint
3002 Market	8-6-2004	E	screens
3002 Market	8-6-2004	I	weathertight- repair
3002 Market	8-6-2004	I	door locks- repair
3002 Market	7-17-1999	E	chipped paint
3000 Market	3-13-2002	I	over occupancy
3000 Market	8-18-1999	I	weather stripping
3002 Market	8-18-1999	I	window locks
3002 Market	8-18-1999	I	windows- repair
3002 Market	8-18-1999	I	smoke deceptor- replace
3000 Market	8-18-1999	I	walls- repair/paint
3002 Market	8-18-1999	I	smoke detectors- repair
3000-3002 Market	8-4-1994	E	chipped paint
3000-3002 Market	10-1-1989	E	chipped paint
3000 Market	8-9-1989	I	cracked glass
3000 Market	8-9-1989	I	water heater-gas line- replace
3000 Market	4-22-1983	I	gas lines- replace
3000 Market	4-22-1983	I	gas shut off valve- water heater
3000 Market	4-22-1983	I	blow down leg
3000 Market	8-26-1997	E	grass/yard waste
3000 Market	3-9-1994	E	chipped paint
3000 Market	1-24-1994	I	opening in electric panel box
3000 Market	9-17-1982	I	fire extinguisher
3000 Market	9-17-1982	I	smoke detector
2906 Market	10-28-2004	I	storms
2906 Market	10-28-2004	I	secure flooring
2906 Market	10-26-2004	E	chipped paint
2906 Market	9-21-1999	E	chipped paint
2906 Market	1-4-1986	I	electrical panel- label
2906 Market	1-4-1986	I	water heater flue- repair
2906 Market	1-4-1986	I	water heater release valve- repair
2906 Market	1-4-1986	I	receptacles
2906 Market	1-4-1986	E	siding- repair/replace/paint
2906 Market	1-4-1986	E	windows- repair/replace
2906 Market	1-4-1986	E	sidewalk-repair/ replace
2906 Market	1-4-1986	E	porch corner post
2906 Market	1-4-1986	E	porch- replace
2906 Market	1-4-1986	E	roof- repair/ replace
2906 Market	1-4-1986	E	gutter/downspout system
2906 Market	1-4-1986	E	remove tree
2906 Market	1-4-1986	E	smoke detectors
2906 Market	1-4-1986	E	weatherstripping
2906 Market	1-4-1986	E	window locks
2906 Market	1-4-1986	E	attic ventilation

Violation_Table

2906 Market	1-4-1986	E	storms/screens
2906 Market	3-15-1984	I	blow down leg
2902-2904 Market	4-7-1998	E	chipped paint
2902-2904 Market	4-21-1998	I	outlets
2902-2904 Market	4-21-1998	E	roof- replace
2906 Market	10-28-2004	I	screens
2902-2904 Market	4-21-1998	E	paint/reside
2902-2904 Market	9-26-1993	E	chipped paint
2904 Market	4-23-1992	I	walls- repair/replace
2904 Market	4-23-1992	I	lavatory trap- replace
2902 Market	12-4-1987	I	gas shut off valves
2902 Market	12-4-1987	I	broken windows
2902 Market	12-4-1987	I	fire extinguisher
2904 Market	12-4-1987	I	outlets
2904 Market	12-4-1987	I	blow down leg
2904 Market	12-4-1987	I	gas lines to appliances
2904 Market	12-4-1987	I	fire extinguisher
300 Union	9-19-203	I	screens- repair/replace
300 Union	9-19-203	I	walls- repair
300 Union	9-19-203	I	broken windows
302 Union	9-19-203	I	weather tight
302 Union	9-19-203	I	floor- repair
302 Union	9-19-203	I	broken glass/windows
302 Union	9-19-203	I	sink base- repair
302 Union	9-19-203	I	fire extinguisher- repair
304 Union	9-19-203	I	storms/screens
304 Union	9-19-203	I	smoke detector- repair
304 Union	9-19-203	I	broken glass
306 Union	9-19-203	I	screens/storms
306 Union	9-19-203	I	fire extinguisher- repair
300-306 Union	7-25-2003	E	chipped paint
300-306 Union	7-25-2003	I	attic ventilation
300-306 Union	10-18-2000	E	downspouts- repair
300-306 Union	10-18-2000	E	peeling paint
300 Union	10-18-2000	I	walls- repair
300 Union	10-18-2000	I	GFCI outlet- replace
300 Union	10-18-2000	I	screens/storms
300 Union	10-18-2000	I	outlet covers
302 Union	10-18-2000	I	walls- repair
302 Union	10-18-2000	I	doors- repair
302 Union	10-18-2000	I	broken windows
304 Union	10-18-2000	I	screens
306 Union	10-18-2000	I	storms/screens
306 Union	10-18-2000	I	walls- repair
300-306 Union	9-28-2000	E	chipped paint
300-306 Union	4-20-1997	E	chipped paint
300-306 Union	5-12-1997	E	downspouts- repair
300-306 Union	5-12-1997	E	broken windows/screens
300 Union	5-12-1997	I	smoke detector- repair
300 Union	5-12-1997	I	walls- repair
300 Union	5-12-1997	I	doors- repair/replace

Violation_Table

304 Union	5-12-1997	I	walls- repair
304 Union	5-12-1997	I	weatherstripping
306 Union	5-12-1997	I	walls- repair
306 Union	5-12-1997	I	fire extinguisher
306 Union	5-12-1997	I	gas line- cap
306 Union	5-12-1997	I	thermostat- repair
306 Union	5-12-1997	I	GFCI outlet- replace
300 Union	5-16-1994	I	storms/screens- replace
300-306 Union	5-3-1994	E	chipped paint
300-306 Union	9-17-1991	E	chipped paint
306 Union	9-17-1991	I	cracked glass
306 Union	9-17-1991	I	fire extinguisher
222-228 Union	5-14-2003	E	repair/paint garage
222-228 Union	5-14-2003	E	remove shed
222-228 Union	5-14-2003	I	gas shut off valve
222 Union	5-14-2003	I	weather stripping
222 Union	5-14-2003	I	storms- repair
224 Union	5-14-2003	I	doors- repair
224 Union	5-14-2003	I	gas supply- cap
226 Union	5-14-2003	E	storm door- repair
226 Union	5-14-2003	I	floor- repair
228 Union	5-14-2003	I	weather stripping
222-228 Union	5-3-2003	E	chipped paint
222-228 Union	5-10-2000	E	fascia/soffit- repair/paint
222-228 Union	5-10-2000	E	windows- peeling paint
222-228 Union	5-10-2000	E	junk in yard
222 Union	5-10-2000	E	storms/screens
222 Union	5-10-2000	I	doors- repair/replace
222 Union	5-10-2000	I	broken windows
224 Union	5-10-2000	I	outlet covers
224 Union	5-10-2000	I	weathertight
224 Union	5-10-2000	I	ceilings-paint
224 Union	5-10-2000	I	lavatory-repair
224 Union	5-10-2000	I	screens- replace/repair
228 Union	5-10-2000	I	no electric/water
228 Union	5-10-2000	I	cap electric
228 Union	5-10-2000	I	water heater- replace
228 Union	5-10-2000	I	screens- replace/repair
228 Union	5-10-2000	I	weathertight
228 Union	5-10-2000	I	smoke detector- repair
222-228 Union	5-1-2000	E	chipped paint
222-228 Union	9-17-1998	E	dumping trash- city property
222-228 Union	2-5-1998	E	junk, trash, garbage
222-228 Union	5-12-1997	E	broken windows
222-228 Union	5-12-1997	E	trash, junk, tree limbs
222 Union	5-12-1997	I	weather stripping
222 Union	5-12-1997	I	gas line- cap
222 Union	5-12-1997	I	ceilings- repair
222 Union	5-12-1997	I	threshold- rotted
222 Union	5-12-1997	I	drains- repair
224 Union	5-12-1997	I	fire extinguisher

Violation_Table

224 Union	5-12-1997	I	gas line- cap
226 Union	5-12-1997	I	walls- repair (holes)
226 Union	5-12-1997	I	floors- repair
226 Union	5-12-1997	I	drains- repair
226 Union	5-12-1997	I	smoke detector- repair
226 Union	5-12-1997	I	fire extinguisher
226 Union	5-12-1997	I	furnace flue- repair
226 Union	5-12-1997	I	water heater flue- repair
226 Union	5-12-1997	I	cover furnace
226 Union	5-12-1997	I	gas line- plug/cap
226 Union	5-12-1997	I	weather stripping
226 Union	5-12-1997	E	front steps- repair
228 Union	5-12-1997	I	doors- repair
228 Union	5-12-1997	I	walls- repair (holes)
228 Union	5-12-1997	I	floors- repair
228 Union	5-12-1997	I	ceiling- repair
228 Union	5-12-1997	I	gas line- cap
228 Union	5-12-1997	I	switched/ outlets- replace
228 Union	5-12-1997	I	infestation- pests
222-228 Union	5-11-1997	E	chipped paint
223 Union	5-29-1995	I	floors- unsanitary
223 Union	5-29-1995	I	ceiling/walls- greasy
223 Union	5-29-1995	I	refuse/rubbish- improper storage
223 Union	5-29-1995	I	plumbing- unsafe
223 Union	5-29-1995	I	fixtures- unsafe
223 Union	5-29-1995	I	infestation- pests
226 Union	10-1-1993	I	infestation- vermin
226 Union	10-1-1993	E	ground contamination (illness)
222 Union	6-3-1994	I	furnace- replace
224 Union	6-3-1994	I	no water/plumbing
224 Union	6-3-1994	I	storms- replace
224 Union	6-3-1994	I	gas line- cap
226 Union	6-3-1994	I	broken windows
226 Union	6-3-1994	I	walls- repair (holes)
228 Union	6-3-1994	I	water heater plate
222-228 Union	6-3-1994	I	blow down leg- repair
222-228 Union	6-3-1994	I	screens
222-228 Union	6-3-1994	I	ceilings- repair
222-228 Union	6-3-1994	E	holes in yard
222-228 Union	8-2-1993	I	walls (holes)
222-228 Union	8-2-1993	I	floors- repair (warped/unfinished)
222-228 Union	8-2-1993	I	ceilings- repair (holes)
228 Union	1-20-1992	I	doors- replace
222 Union	12-2-1991	E	romex- remove
224 Union	12-2-1991	I	main water leak
226 Union	12-2-1991	I	outlet covers- replace
226 Union	12-2-1991	I	peeling paint
228 Union	12-2-1991	I	weather stripping
228 Union	12-2-1991	I	smoke detector- repair/replace
222 Union	10-21-1991	I	unmaintained
222 Union	10-21-1991	I	floors/ceilings- dirty

Violation_Table

222 Union	10-21-1991	E	garage- garbage stored
222 Union	10-21-1991	I	organic/ hazardous chemicals stored
222 Union	10-21-1991	I	infestation- vermin
222 Union	10-21-1991	I	wiring- improper
222 Union	10-21-1991	I	unsanitary
222 Union	10-21-1991	I	fixtures- unmaintained
222-228 Union	10-1-1991	E	chipped paint
222-228 Union	10-1-1991	E	romex on building
222 Union	10-1-1991	I	infestation- vermin
224 Union	10-1-1991	I	water main leak (at shut off)
224 Union	10-1-1991	I	outlets- rewire
226 Union	10-1-1991	I	outlets- rewire/ replace covers
226 Union	10-1-1991	I	walls- repair (holes)
226 Union	10-1-1991	I	smoke detector- repair
228 Union	2-14-1991	E	debris
228 Union	2-14-1991	E	fence/remove posts
228 Union	2-14-1991	I	no water
228 Union	2-14-1991	I	water heater- no vent
228 Union	2-14-1991	I	gas- no vent
228 Union	2-14-1991	E	peeling paint- windows
228 Union	2-14-1991	I	peeling paint
228 Union	2-14-1991	I	smoke detector- repair
228 Union	2-14-1991	I	improper outlets (need electrician)
226 Union	10-23-1989	I	secure electric
226 Union	10-23-1989	I	junction box- cover
226 Union	10-23-1989	I	broken glass (from windows)
226 Union	10-23-1989	I	lavatory- no trap
226 Union	10-23-1989	I	smoke detector- repair
222 Union	1-23-1989	E	debris
222 Union	1-23-1989	E	peeling paint
222 Union	1-23-1989	I	unfinished/rough floors
222 Union	1-23-1989	I	improper plumbing
222-228 Union	1-5-1988	I	water heater- improper installation
222-228 Union	1-5-1988	I	blow down leg
222-228 Union	1-5-1988	I	improper pressure- water heater
222-228 Union	1-5-1988	I	outlets- replace (improper)
222-228 Union	1-5-1988	I	cracked windows
222-228 Union	1-5-1988	I	improper drainage
222-228 Union	1-5-1988	I	unprotected surfaces
222-228 Union	1-5-1988	I	screens/storms
222-228 Union	1-5-1988	I	electricity- inadequate
222-228 Union	1-5-1988	I	infestation- vermin
222 Union	1-5-1988	E	cluttered
222 Union	1-5-1988	I	leaking windows
222 Union	1-5-1988	I	ceilings- unfinished
222 Union	1-5-1988	I	walls- mildewed
222 Union	1-5-1988	I	floors- repair (holes)
222 Union	8-11-1987	I	fire extinguisher
222 Union	8-11-1987	I	smoke detector
222 Union	8-11-1987	I	leaky windows
222 Union	8-11-1987	I	junction box-cover

Violation_Table

222 Union	8-11-1987	I	walls- mildewed
222 Union	8-11-1987	I	ceiling- unfinished
222 Union	8-11-1987	I	floor- repair (holes)
222 Union	8-11-1987	I	infestation- vermin
222-228 Union	8-11-1987	I	blow down legs
222-228 Union	8-11-1987	I	outlets
226 Union	8-11-1987	I	fire extinguisher
226 Union	8-11-1987	I	peeling paint
226 Union	8-11-1987	I	cracked windows
222-228 Union	8-11-1987	I	inadequate rainwater drainage
222-228 Union	8-11-1987	E	wood surfaces- unfinished
222-228 Union	8-11-1987	E	screens
222-228 Union	8-11-1987	E	peeling paint
224 Union	8-11-1987	I	walls/floor- holes
226 Union	8-11-1987	I	gas shut off valves
222 Union	6-10-1987	I	leaky windows
222 Union	6-10-1987	I	walls- mildewed
222 Union	6-10-1987	I	floors- holes
222-228 Union	8-5-1986	E	cars stored on public streets (repair)
222-228 Union	8-5-1986	E	junk/junk vehicles
224 Union	10-17-1983	I	water heater- gas valve
222 Union	10-17-1983	I	window panes- repair
226 Union	10-17-1983	I	window panes- repair
222 Union	10-17-1983	I	fire extinguisher- repair
222 Union	unknown	I	blow down leg
222 Union	unknown	I	gas shut off valve
222 Union	unknown	I	furnace- gas valve
222 Union	unknown	I	broken windows/panes
222 Union	unknown	I	fire extinguisher
222 Union	unknown	I	smoke detectors
224 Union	unknown	I	flooring- replace
224 Union	unknown	I	water heater- gas shut off valve
224 Union	unknown	I	fire extinguisher
224 Union	unknown	I	smoke detector
226 Union	unknown	I	broken windows/panes
224 Union	5-21-1981	I	ceilings/soffits- repair
224 Union	5-21-1981	I	water lines- deteriorated
224 Union	5-21-1981	I	walls- repaired
224 Union	5-21-1981	I	ceiling leaks- damage
224 Union	5-21-1981	I	windows- repair
224 Union	5-21-1981	I	floors- unsanitary/ deteriorated
335-341 Columbus	4-28-2005	E	chipped paint
335-341 Columbus	3-19-2002	E	chipped paint
335-341 Columbus	3-12-1999	E	chipped paint
335-341 Columbus	7-26-1996	I	smoke detector
347 Columbus	4-2-1993	I	bad GFCI
2918 Columbia	4-2-1993	I	smoke detector- repair
3038 Columbia	4-2-1993	I	smoke detector- repair
3040 Columbia	4-2-1993	I	smoke detector- repair
314 Ordinance	4-2-1993	I	overcrowded
315 Ordinance	4-2-1993	I	infestation- vermin

Violation_Table

310 Union	4-2-1993	I	infestation- vermin
310 Union	4-2-1993	I	broken windows
310 Union	4-2-1993	I	no emergency egress
311 Union	4-2-1993	I	infestation- vermin
312 Union	4-2-1993	I	smoke detector- repair
318 Union	4-2-1993	I	bad GFCI
310-318 Union	4-2-1993	E	uncovered GFCI
339 Columbus	3-30-2005	I	doors- repair
341 Columbus	3-30-2005	I	GSI outlet- repair/secure
341 Columbus	3-30-2005	I	floor- repair
345 Columbus	3-30-2005	I	doors- repair
347 Columbus	3-30-2005	I	weather stripping
347 Columbus	3-30-2005	I	floors- repair
349 Columbus	3-30-2005	I	doors- repair
2908 Columbia	3-30-2005	I	walls- repair (holes)
2920 Columbia	3-30-2005	I	GFCI outlet
3026 Columbia	3-30-2005	I	overhaul
314 Union	3-30-2005	I	floor- repair
314 Union	3-30-2005	I	doors- repair
314 Union	3-30-2005	E	outlets- repair
312 Union	3-30-2005	E	outlets- repair
311 Union	3-30-2005	I	floor- repair
313 Union	3-30-2005	I	GFCI- repair
318 Ordinance	3-30-2005	I	doors- repair
312 Ordinance	3-30-2005	I	GFCI outlet- repair
310 Ordinance	3-30-2005	I	floors- repair
315 Ordinance	3-30-2005	I	storms- repair
2910 Columbia	9-6-2005	I	dwelling unsafe
2900-2910 Columbia	4-28-2005	E	chipped paint
2900-2910 Columbia	3-19-2002	E	chipped paint
3105 Columbia	7-27-1999	I	smoke detector- repair
3105 Columbia	7-27-1999	I	screens- repair
335 Columbia	7-27-1999	I	electrical service panel- opening
339 Columbia	7-27-1999	I	floor- repair
347 Columbia	7-27-1999	I	screen/storms- repair
2906 Colubia	7-27-1999	I	walls- repair
2906 Colubia	7-27-1999	I	GFCI outlet- secure
2922 Columbia	7-27-1999	I	smoke detector- secure
3030 Columbia	7-27-1999	I	GFCI outlet- secure
3026 Columbia	7-27-1999	I	floor- repair
318 Union	7-27-1999	I	floor- repair
317 Union	7-27-1999	I	switch/outlet- repair
312 Ordinance	7-27-1999	I	weather stripping
319 Ordinance	7-27-1999	I	doors- repair
317 Ordinance	7-27-1999	I	smoke detectors- repair
315 Ordinance	7-27-1999	I	smoke detectors- repair
2900-2910 Columbia	3-12-1999	E	chipped paint
2900-2910 Columbia	3-12-1999	E	no accessory building
2906 Columbus	6-12-1996	I	fire extinguisher- repair
2901-2907 Columbia	12-7-1983	I	gas shut off valves
2901 Columbia	12-7-1983	I	blow down leg

Violation_Table

2905 Columbia	12-7-1983	I	blow down leg
2907 Columbia	12-7-1983	I	blow down leg
2901 Columbia	12-7-1983	I	gas shut off valve
2901 Columbia	12-7-1983	I	water pipes- replace
2901 Columbia	12-7-1983	I	broken windows/panes
2901 Columbia	12-7-1983	I	fire extinguisher
2901 Columbia	12-7-1983	I	smoke detectors
2905 Columbia	12-7-1983	I	broken windows
2905 Columbia	12-7-1983	I	fire extinguisher
2905 Columbia	12-7-1983	I	smoke detectors
2907 Columbia	12-7-1983	I	floor- loose boards/hole
2907 Columbia	12-7-1983	I	broken windows
2907 Columbia	12-7-1983	I	fire extinguisher
2907 Columbia	12-7-1983	I	smoke detectors
2901-2907 Columbia	12-7-1983	I	inadequate electric
2900-2904 Columbia	11-17-1983	I	gas shut off valves
2900-2904 Columbia	11-17-1983	I	blow down leg
2904 Columbia	11-17-1983	I	furnace- gas valve
2900 Columbia	11-17-1983	E	broken window/panes
2900-2904 Columbia	11-17-1983	I	fire extinguisher
1941 Columbia	11-17-1983	I	fire extinguisher
2900-2904 Columbia	11-17-1983	I	smoke detector
1941 Columbia	11-17-1983	I	smoke detector
2901-2907 Columbia	11-17-1983	I	gas valves
2901 Columbia	11-17-1983	I	blow down leg
2905 Columbia	11-17-1983	I	blow down leg
2907 Columbia	11-17-1983	I	blow down leg
2901 Columbia	11-17-1983	I	inadequate water pressure
2901 Columbia	11-17-1983	E	broken windows/panes
2901-2907 Columbia	11-17-1983	I	smoke detectors
2901-2907 Columbia	11-17-1983	I	fire extinguishers
2901 Columbia	11-17-1983	E	broken windows/panes
2905 Columbia	11-17-1983	E	broken windows/panes
2907 Columbia	11-17-1983	E	broken windows/panes
2907 Columbia	11-17-1983	I	floor- repair (holes)
2904 Columbia	6-7-1979	E	handrail- repair
2904 Columbia	6-7-1979	I	circuits (inadequate)
2904 Columbia	6-7-1979	I	furnace- secure ventilation
2904 Columbia	6-7-1979	I	furnace- wiring- replace
2904 Columbia	6-7-1979	I	water heater- gas shut off valve
2904 Columbia	6-7-1979	I	blow down leg
2904 Columbia	6-7-1979	I	water heater vent- seal
2907 Columbia	6-7-1979	I	furnace- secure ventilation
2907 Columbia	6-7-1979	I	furnace wiring- replace
2907 Columbia	6-7-1979	I	blow down leg
2907 Columbia	6-7-1979	I	water heater- gas shut off valve
2907 Columbia	6-7-1979	I	windows- seal
2907 Columbia	6-7-1979	I	walls- repair (holes)
2901 Columbia	6-5-1979	I	furnace- secure ventilation
2901 Columbia	6-5-1979	I	furnace wiring- replace
2901 Columbia	6-5-1979	I	enclose furnace

Violation_Table

2901 Columbia	6-5-1979	I	water heater- gas shut off valve
2901 Columbia	6-5-1979	I	blow down leg
2901 Columbia	6-5-1979	I	fire extinguisher
2901 Columbia	6-5-1979	I	walls- replace (broken)
2901 Columbia	6-5-1979	E	gravel parking lot
2825 Columbia	6-5-1979	I	furnace- secure ventilation
2825 Columbia	6-5-1979	I	furnace-wiring- replace
2825 Columbia	6-5-1979	E	handrail
2825 Columbia	6-5-1979	I	fire extinguisher
2405 Columbia	5-24-1979	I	furnace- secure ventilation
2825 Columbia	5-24-1979	I	furnace-wiring- replace
2825 Columbia	5-24-1979	I	blow down leg
2825 Columbia	5-24-1979	I	water heater- gas shut off valve
2825 Columbia	5-24-1979	I	fire extinguisher
2612 Columbia	5-24-1979	I	furnace-wiring- replace
2612 Columbia	5-24-1979	I	furnace- secure ventilation
2612 Columbia	5-24-1979	I	fire extinguisher
2612 Columbia	5-24-1979	I	blow down leg
2612 Columbia	5-24-1979	I	water heater- gas shut off valve
2612 Columbia	5-24-1979	I	water heater- secure vent
2914-2924 Columbia	4-28-2005	E	chipped paint
2914-2924 Columbia	3-19-2002	E	chipped paint
2914-2924 Columbia	3-12-1999	E	chipped paint
2916-2922 Columbia	7-26-96	I	smoke detectors
2916-2922 Columbia	7-26-1996	E	chipped paint
310-318 Ordinance	4-28-2005	E	chipped paint
3115 Columbia	4-28-2005	E	chipped paint
310-318 Ordinance	3-19-2002	E	chipped paint
3115 Columbia	3-19-2002	E	chipped paint
310-318 Ordinance	3-12-1999	E	chipped paint
3115 Columbia	3-12-1999	E	chipped paint
314 Ordinance	7-26-1996	I	smoke detectors- repair
312 Ordinance	7-26-1996	I	smoke detectors- repair
312 Ordinance	3-31-1993	I	floor- repair (buckles)
312 Ordinance	3-31-1993	I	overcrowded
316 Ordinance	12-6-1893	I	ceilings- repair
316 Ordinance	12-6-1893	I	floors- repair
316 Ordinance	12-6-1893	I	broken windows/panes
316 Ordinance	12-6-1893	I	walls- repair (holes)
316 Ordinance	12-6-1893	I	subfloor- repair/replace
314 Ordinance	12-6-1893	I	subfloor- repair/replace
314 Ordinance	12-6-1893	I	fire extinguisher
314 Ordinance	12-6-1893	I	smoke detectors
312 Ordinance	12-6-1893	I	peeling paint
318 Ordinance	12-6-1893	I	smoke detector
318 Ordinance	12-6-1893	I	broken windows/panes
318 Ordinance	12-6-1893	I	fire extinguisher
310 Ordinance	12-6-1893	I	smoke detectors
310 Ordinance	12-6-1893	I	fire extinguisher
3115 Columbia	12-6-1893	I	smoke detectors
311-319 Ordinance	4-28-2005	E	chipped paint

Violation_Table

3205 Columbia	4-28-2005	E	chipped paint
311-319 Ordinance	3-19-2002	E	chipped paint
3205 Columbia	3-19-2002	E	chipped paint
311-319 Ordinance	3-12-1999	E	chipped paint
3205 Columbia	7-26-1996	E	chipped paint
311-319 Ordinance	7-26-1996	E	chipped paint
315 Ordinance	3-31-1993	I	infestation- vermin
311-317 Ordinance	12-5-1983	I	gas shut off valve
315 Ordinance	12-5-1983	I	blow down leg
317 Ordinance	12-5-1983	I	blow down leg
313 Ordinance	12-5-1983	I	floor- repair
319 Ordinance	12-5-1983	I	floor- repair
315 Ordinance	12-5-1983	I	outlet coverings
319 Ordinance	12-5-1983	I	walls- repair (holes)
319 Ordinance	12-5-1983	I	switch coverings
313 Ordinance	12-5-1983	I	walls- repair (holes)
317 Ordinance	12-5-1983	I	broken windows/ panes
313 Ordinance	12-5-1983	I	broken windows/ panes
311-315 Ordinance	12-5-1983	I	fire extinguisher
3205 Columbia	12-5-1983	I	fire extinguisher
311-315 Ordinance	12-5-1983	I	smoke detectors
3205 Columbia	12-5-1983	I	smoke detectors
313 Ordinance	12-5-1983	I	doors- replace/repair
311-319 Ordinance	12-5-1983	I	inadequate electrical
3205 Columbia	12-5-1983	I	inadequate electrical
3020-3030 Columbia	4-28-2005	E	chipped paint
3020-3030 Columbia	3-19-2002	E	chipped paint
3020-3030 Columbia	3-12-1999	E	chipped paint
345-351 Columbus	4-28-2005	E	chipped paint
311-319 Union	4-28-2005	E	chipped paint
3105 Columbia	4-28-2005	E	chipped paint
319 Union	9-13-2002	I	fire extinguisher- repair
319 Union	9-13-2002	I	no water (kitchen)
319 Union	9-13-2002	I	GFCI- wont trip
319 Union	9-13-2002	I	smoke detector- hardwire- replace
319 Union	9-13-2002	I	floors- repair (weak/missing tile)
319 Union	9-13-2002	I	storm doors-repair
311-319 Union	3-19-2002	E	chipped paint
3105 Columbia	3-19-2002	E	chipped paint
319 Union	8-9-2002	I	poor living conditions
3105 Columbia	3-19-2002	E	chipped paint
311-319 Union	3-19-2002	E	chipped paint
311-319 Union	3-12-1999	E	chipped paint
3105 Columbia	3-12-1999	E	chipped paint
313 Union	7-26-1996	I	plumbing leaks
315 Union	7-26-1996	I	smoke detectors- repair
311-319 Union	7-26-1996	E	chipped paint
3105 Columbia	7-26-1996	E	chipped paint
311 Union	3-31-1993	I	infestation- vermin
313-317 Union	11-16-1983	E	broken windows/panes
310-318 Union	4-28-2005	E	chipped paint

Violation_Table

3015 Columbia	4-28-2005	E	chipped paint
312 Union	9-30-2004	I	ceiling- collapsed
310-318 Union	3-19-2002	E	chipped paint
3015 Columbia	3-19-2002	E	chipped paint
310-318 Union	3-12-1999	E	chipped paint
3015 Columbia	3-12-1999	E	chipped paint
3015 Columbia	7-26-1996	I	outlet covers
314 Union	7-26-1996	I	smoke alarms- secure
318 Union	7-26-1996	I	bad GFCI
310-318 Union	7-26-1996	E	uncovered GFCI
310 Union	7-26-1996	I	infestation- vermin
312 Union	7-26-1996	I	smoke detectors- secure
314 Union	11-16-1983	E	broken windows/panes
316 Union	11-16-1983	I	smoke detectors
316 Union	11-16-1983	I	fire extinguisher
316 Union	11-16-1983	I	windows- painted open
2915 Valley	11-15-2002	I	weather stripping
2915 Valley	11-15-2002	I	water leaks- secure fixtures
2915 Valley	11-15-2002	I	electrical switched- secure
2915 Valley	11-15-2002	I	screens
2915 Valley	11-15-2002	I	GFCI wont trip
2917 Valley	11-15-2002	I	switches- repair
2917 Valley	11-15-2002	I	fire extinguisher
2917 Valley	11-15-2002	I	electrical panel- plug vacant
2917 Valley	4-14-1997	I	blow down leg- replace
2917 Valley	4-14-1997	I	chimney- repair
2917 Valley	4-14-1997	I	window locks
2917 Valley	7-12-1996	E	weeds/brush/tree limbs/junk/trash
2921 Valley	2-8-2005	E	junk/appliances
2921 Valley	2-8-2005	I	windows broken
2921 Valley	2-8-2005	I	storms- broken
2921 Valley	2-8-2005	I	electrical switches- repair
2921 Valley	2-8-2005	I	weather stripping
2921 Valley	2-8-2005	I	door locks
2923 Valley	2-8-2005	I	doors- repair/replace
2925 Valley	2-8-2005	I	storms/screens- repair/replace
2925 Valley	2-8-2005	I	doors- repair
2925 Valley	2-8-2005	I	breaker- secure
2925 Valley	2-8-2005	I	weather stripping
2927 Valley	2-8-2005	I	doors- repair/replace
2927 Valley	2-8-2005	I	ceiling- finish
2921 Valley	1-19-2001	I	ceilings/walls- repair
2921 Valley	1-19-2001	I	fire extinguisher
2921 Valley	1-19-2001	I	outlets- secure
2921 Valley	1-19-2001	I	gas line- cap (unused)
2921 Valley	1-19-2001	I	weather stripping
2921 Valley	1-19-2001	I	switches- repair
2921 Valley	1-19-2001	I	smoke detectors- repair/replace
2921 Valley	1-19-2001	I	outlet covers
2923 Valley	1-19-2001	I	floors- repair
2923 Valley	1-19-2001	I	ceilings/walls- repair

Violation_Table

2925 Valley	1-19-2001	I	weather stripping
2925 Valle	1-19-2001	I	floors- repair/replace
2925 Valle	1-19-2001	I	storms
2927 Valley	1-19-2001	I	broken windows
2927 Valley	1-19-2001	I	floors- repair/replace
2927 Valley	1-19-2001	I	doors- repair
2921-2927 Valley	1-5-2001	E	chipped paint
2921 Valley	7-15-1999	E	trash- hole in ground
2921 Valley	1-8-1998	E	trash
2921 Valley	11-26-1996	I	weather stripping
2921 Valley	11-26-1996	I	electrical switches- repair
2921 Valley	11-26-1996	I	screens- repair
2925 Valley	11-26-1996	I	electrical switches- replace
2925 Valley	11-26-1996	I	weather stripping
2925 Valley	11-26-1996	I	handrail- repair
2925 Valley	11-26-1996	I	lavatory- repair
2927 Valley	11-26-1996	I	floor- repair
2927 Valley	11-26-1996	I	handrail- repair
2921-2927 Valley	10-29-1996	E	chipped paint
2921-2927 Valley	10-9-1995	E	junk/wood/appliances
2921 Valley	11-9-1994	I	P/T valve on waterheater
2925 Valley	11-9-1994	I	infestation- vermin
2927 Valley	11-9-1994	I	weathertight
2923 Valley	9-22-1994	I	no ceiling
2923 Valley	9-22-1994	I	no lavatory
2923 Valley	9-22-1994	I	outlet covers
2923 Valley	9-22-1994	I	doors- secure
2923 Valley	9-22-1994	I	infestation- vermin
2923 Valley	9-22-1994	I	facilities unmaintained
2923 Valley	9-22-1994	I	floors/walls ceilings- (holes)
2921 Valley	8-17-1993	I	infestation- vermin
2921 Valley	8-17-1993	I	broken glass/windows
2921 Valley	8-17-1993	I	cover outlets
2921 Valley	8-17-1993	I	storms/screens- repair/replace
2927 Valley	8-17-1993	I	electrical box- cover
2927 Valley	8-17-1993	I	infestation- vermin
2927 Valley	8-17-1993	I	broken windows
2925 Valley	8-21-1990	I	broken windows
2925 Valley	8-21-1990	I	handrail- repair
2927 Valley	8-21-1990	I	smoke detectors- secure
2927 Valley	8-21-1990	I	railing- secure/repair
2927 Valley	8-21-1990	I	doors- repair/secure
2921 Valley	8-21-1990	E	handrail
2921 Valley	8-21-1990	I	broken windows
2921-2125	8-11-1987	I	blow down legs
2921-2125	8-11-1987	I	no hand rails
2921-2927	8-11-1987	I	smoke detectors
2921-2927	8-11-1987	I	fire extinguishers
2921-2927	8-11-1987	E	peeling paint
2925 Valley	8-11-1987	I	peeling paint
2923 Valley	8-11-1987	I	broken windows

Violation_Table

2923 Valley	8-11-1987	I	inadequate doors
2923 Valley	8-11-1987	I	electrical short
2923 Valley	8-11-1987	I	furnace unsafe
2923 Valley	8-11-1987	I	inadequate doors
2927 Valley	8-11-1987	I	electrical panel- unprotected
2927 Valley	8-11-1987	I	lighting- unsecure (dangling)
2921-2927 Valley	8-11-1987	I	screens
2921-2927 Valley	8-11-1987	I	walls- repair (holes)
2921-2927 Valley	8-11-1987	I	infestation- vermin
2921-2927 Valley	8-11-1987	I	cracked windows
2921-2927 Valley	8-11-1987	I	unprotected wood surfaces
2921-2927 Valley	8-11-1987	I	cracked outlets
2921 Valley	8-2-1989	I	screens- replace
2921 Valley	8-2-1989	E	porch- repair
2921 Valley	8-2-1989	I	walls- holes
2925 Valley	8-2-1989	I	walls- holes
2925 Valley	8-2-1989	I	peeling paint
2925 Valley	8-2-1989	I	gas shut off valve
3003 Valley	7-23-1997	E	trash
3003 Valley	7-23-1997	I	smoke detectors- repair
3003 Valley	7-23-1997	I	infestation- vermin
3003 Valley	7-23-1997	I	gas line-ca[(unused)
3003 Valley	7-23-1997	I	ceiling- repair
3003 Valley	6-30-1997	E	chipped paint
3003 Valley	7-15-1997	E	garbage/mattress/bed frame
3003 Valley	9-25-1995	E	trash
3009 Valley	3-26-2003	I	gas line - cap
3009 Valley	3-26-2003	I	fire extinguisher
3009 Valley	3-26-2003	I	smoke detectors
3009 Valley	6-26-2003	E	junk/trees
3009 Valley	6-26-2003	I	outlet- repair (no power)
3009 Valley	6-26-2003	I	rotted wood- windows
3009 Valley	6-26-2003	I	smoke detectors-repair/ replace
3009 Valley	6-9-2003	E	chipped paint
3009 Valley	6-24-1998	I	doors- repair/replace
3009 Valley	6-24-1998	I	smoke detectors
3009 Valley	6-22-1998	E	chipped paint
710 Plane	1-10-2003	I	fire extinguisher- repair
710 Plane	1-10-2003	I	screens
710 Plane	1-10-2003	I	walls- repair (holes)
710 Plane	1-3-2003	E	chipped paint
3109 Valley	1-15-1998	E	windows- unfinished wood
3109 Valley	1-15-1998	I	screens- repair/replace
3109 Valley	1-15-1998	I	fire extinguisher
3109 Valley	1-15-1998	I	outlets- secure
3109 Valley	1-15-1998	I	floors- repair
3109 Valley	1-22-1997	E	chipped paint
3109 Valley	3-1-1992	I	fire extinguisher
3109 Valley	3-1-1992	I	smoke detector- repair/replace
3109 Valley	3-1-1992	I	water heater- combustion air
3109 Valley	3-1-1992	I	blow down leg

Violation_Table

3109 Valley	3-1-1992	I	water heater- gas shut off/union
3109 Valley	3-1-1992	I	broken windows
3109 Valley	3-1-1992	I	outlet covers
3109 Valley	3-1-1992	I	toilet- repair/replace
3109 Valley	3-1-1992	I	storms/screens
3109 Valley	3-1-1992	I	furnace- gas shut off
3101 Valley	12-212004	I	floor- repair
3101 Valley	12-212004	I	screens
3101 Valley	12-212004	I	broken windows
3101 Valley	12-212004	I	smoke detectors- repair
3101 Valley	12-212004	I	doors- repair
3103 Valley	12-212004	I	screens
3105 Valley	12-212004	I	ceiling- repair
3105 Valley	12-212004	I	broken windows
3103 Valley	12-212004	I	fire extinguisher
3013 Valley	8-17-2001	I	no electric- bathroom
3101 Valley	8-17-2001	I	smoke detectors- repair
3101 Valley	8-17-2001	I	screens
3101 Valley	8-17-2001	I	electrical switches- repair
3101 Valley	8-17-2001	I	broken windows
3101 Valley	8-17-2001	I	gas shut off- cap
3015 Valley	8-17-2001	I	ceiling- repair
3015 Valley	8-17-2001	I	smoke detectors- repair
3015 Valley	8-17-2001	I	storms/screens
3015 Valley	8-17-2001	I	broken windows
3015 Valley	8-17-2001	I	gas shut off- cap
3101 Valley	8-17-2001	I	ceiling- repair/paint
3103 Valley	8-17-2001	I	storms/screens
3103 Valley	8-17-2001	I	smoke detectors- repair
3103 Valley	8-17-2001	I	outlet/switch- covers
3103 Valley	8-17-2001	I	fire extinguisher
3013-3103 Valley	3-22-1999	E	screens- repair
3013-3103 Valley	3-22-1999	I	storms/screens- replace
3013 Valley	3-22-1999	I	exhaust fan- repair
3013 Valley	3-22-1999	I	GFCI outlet- repair
3013 Valley	3-22-1999	I	broken windows
3013 Valley	3-22-1999	I	fire extinguisher
3013 Valley	3-22-1999	I	cover switches
3015 Valley	3-22-1999	I	floor- repair
3015 Valley	3-22-1999	I	fire extinguisher
3015 Valley	3-22-1999	I	cover switches
3015 Valley	3-22-1999	I	storms/screens- repair
3015 Valley	3-22-1999	I	doors- repair
3101 Valley	3-22-1999	I	floors- repair
3101 Valley	3-22-1999	I	smoke dectector- repair/replace
3101 Valley	3-22-1999	I	walls- repair (holes)
3101 Valley	3-22-1999	I	doors- repair
3101 Valley	3-22-1999	I	vents- repair
3103 Valley	3-22-1999	I	flooring- repair
3103 Valley	3-22-1999	I	broken windows
3103 Valley	3-22-1999	I	fire extinguisher

Violation_Table

3103 Valley	10-3-1996	E	peeling paint
3103 Valley	10-3-1996	I	weather tight
3013 Valley	11-16-1992	I	secure lavatory
3013 Valley	11-16-1992	I	fire extinguisher
3013 Valley	11-16-1992	I	storms/screens- replace
3015 Valley	11-16-1992	I	smoke detectors- repair
3015 Valley	11-16-1992	I	screens- replace
3015 Valley	11-16-1992	I	secure lavatory
3015 Valley	11-16-1992	I	fire extinguisher
3103 Valley	6-8-1992	E	garbage problems (yard)
3101 Valley	6-8-1992	E	garbage (yard)
3101 Valley	11-16-1992	I	secure lavatory
3101 Valley	11-16-1992	I	windows missing
3101 Valley	11-16-1992	I	screens- replace
3101 Valley	11-16-1992	I	fire extinguisher
3101 Valley	11-16-1992	I	doors- repair/replace
3101 Valley	11-16-1992	I	vents- repair
3103 Valley	11-16-1992	I	storms- repair/replace
3103 Valley	11-16-1992	I	screens- repair/replace
3103 Valley	11-16-1992	I	secure lavatory
3103 Valley	11-16-1992	I	fire extinguisher
3103 Valley	8-18-1992	E	holes in yard
3103 Valley	8-18-1992	I	reset lavatory
3103 Valley	8-18-1992	I	switches/outlet covers
3103 Valley	8-18-1992	I	fire extinguisher
3103 Valley	8-18-1992	I	smoke detectors
3103 Valley	8-18-1992	E	cluttered yard
3015 Valley	8-18-1992	I	doors- repair
3015 Valley	8-18-1992	I	vents
3015 Valley	8-18-1992	I	smoke detector- repair
3015 Valley	8-18-1992	I	screens- repair/replace
3101 Valley	8-18-1992	I	switches/outlet- covers
3101 Valley	8-18-1992	I	screens/storms
3101 Valley	8-18-1992	I	windows missing
3101 Valley	8-18-1992	I	broken windows
3103 Valley	8-18-1992	I	switches/outlet- covers
3103 Valley	8-18-1992	I	windows missing
3103 Valley	8-18-1992	I	screens/storms
3103 Valley	8-18-1992	I	broken windows
3015 Valley	3-4-1992	I	smoke detector- repair
3015 Valley	3-4-1992	I	storms- repair
3015 Valley	3-4-1992	I	combustion air furnace
3015 Valley	3-4-1992	I	vents
3013-3103 Valley	5-25-1988	I	floors- replace
3013-3103 Valley	5-25-1988	I	walls/ceilings- repair
3013-3103 Valley	5-25-1988	I	machine hookups- replace
3013-3103 Valley	5-25-1988	I	doors- repair/replace
3013-3103 Valley	5-25-1988	I	fixtures- replace
3013-3103 Valley	5-25-1988	I	peeling paint
3013-3103 Valley	5-25-1988	I	door locks
3013-3103 Valley	5-25-1988	E	weather stripping

Violation_Table

3013-3103 Valley	5-25-1988	E	peeling paint
3013-3103 Valley	5-25-1988	E	crawl space- vapor barrier
3013-3103 Valley	5-25-1988	E	awnings- repair/replace
3013-3103 Valley	5-25-1988	E	sidewalks/stoops- repair/replace
3013-3103 Valley	5-25-1988	E	eaves/soffits- repair/replace
3013-3103 Valley	5-25-1988	E	gutters/downspouts
3013-3103 Valley	5-25-1988	E	sewer cleanout- seal
3013-3103 Valley	5-25-1988	E	faucets- repair/remove
3013-3103 Valley	5-25-1988	E	roof- replace
3013-3103 Valley	5-25-1988	I	railings
3013-3103 Valley	5-25-1988	I	attic insulation
3013-3103 Valley	5-25-1988	I	electrical service- replace
3013-3103 Valley	5-25-1988	I	GFCI- rewire
3013-3103 Valley	5-25-1988	I	outlets- rewire
3013-3103 Valley	5-25-1988	I	smoke detectors- hardwire
3013-3103 Valley	5-25-1988	I	furnace- enclose
3013-3103 Valley	5-25-1988	I	furnaces- replace
3013-3103 Valley	5-25-1988	I	furnace- combustion air
3103 Valley	5-25-1988	I	water heater- replace
3103 Valley	5-25-1988	I	gas piping- replace